



Title:	Document Version:
D14.1 Analysis of the Demo sites technical data integration and demonstration planning	1.0

Project Number:	Project Acronym:	Project Title:
H2020-731205	WiseGRID	Wide scale demonstration of Integrated Solutions for Euro- pean Smart Grid

Contractual Delivery Date:	Actual Delivery Date:	Deliverable Type*-Security*:		
M19 (May 2018)	M19 (May 2018)	R-PU		

*Type: P: Prototype; R: Report; D: Demonstrator; O: Other.

**Security Class: PU: Public; PP: Restricted to other programme participants (including the Commission); RE: Restricted to a group defined by the consortium (including the Commission); CO: Confidential, only for members of the consortium (including the Commission).

Responsible:	Organisation:	Contributing WP:	
Álvaro Nofuentes	ETRA	WP14 & WP15	

Authors (organization):

Álvaro Nofuentes (ETRA), Foivos Palaiogiannis (ICCS), Ine Swennen (ECO-EID), Vincent Dierickx (ECO-EID), Jim Williame (ECO), Stendert van Soens (ECO), Jan de Pauw (ECO), Dimitris Stratogiannis (HEDNO), Stamatia Gkiala-Fikari (HEDNO), Katerina Chira (HEDNO), Maria Symboni (HEDNO) Valia Iliopoulou (AEA), Francesca Santori (ASM), Tommaso Bragatto (ASM) Francesco Bellesini (EMOT), Joachim Jacob (PARTA), José Luis Poveda (ENER), José Soriano (ENER).

Abstract:

This document reports the work performed within Tasks 14.1 "Analysis of the Demo sites technical data" and Task 15.1 "Demonstration activities planning". In this document it is possible to find information about how the deployment and demonstration of the WiseGRID tools are expected to be performed in the different Pilot Sites taking into account the current and future available infrastructure.

Keywords:

Pilot Sites, Testing, Demonstration, Deployment, Planning, Infrastructure, Use Case, Tool

ETRA I+D INVESTIGACIÓN Y DESARROLLO, S.A.

Avda. Tres Forques, 147 46014 Valencia (España) Tel. +34 96 313 40 82 Fax +34 96 350 32 34 http://www.wisegrid.eu amarias.etraid@grupoetra.com





Revision History

Revision	Date	Description	Author (Organisation)		
V0.0	01.03.2018	New document	ETRA		
V0.1	01.05.2018	First round of contributions	ETRA, ENER, AEA, HEDNO, ECO, ASM, PARTA, EMOT		
V0.2	15.05.2018	Second round of contributions	ETRA, ICCS		
V0.3	30.05.2018	Version ready for peer review	ETRA		
V0.4	07.06.2018	Integration of feedback received	ETRA, ECO, HEDNO		
V1.0	10.06.2018	Final refinement and ready for submis- sion	ETRA		







INDEX

List of Figures	
List of Tables	
EXECUTIVE SUMMARY	
1 INTRODUCTION	
1 INTRODUCTION	
 INTRODUCTION PURPOSE OF THE DOCUMENT SCOPE OF THE DOCUMENT 	

2 DESCRIPTION OF THE WISEGRID TOOLS AND USE CASES TO BE TESTED IN EACH PILOT SITE 11

11
11
11
11
12
12
12
12
13
13
13
13

uisearic



3.1	Mesogia	21
	3.1.1 WG Cockpit Pilot Site details checklists	21
	3.1.2 WiseCOOP, WiseCORP, WiseHOME, Pilot Site details checklists	23
3.2	Terni	34
	3.2.1 WG Cockpit Pilot Site details checklists	34
	3.2.2 WiseCOOP, WiseCORP, WiseHOME, WG RESCO and WG STaaS VPP Pilot S checklists	ite details 36
	3.2.3 WiseEVP Pilot Site details checklist	40
3.3	Flanders	42
	3.3.1 WiseCOOP, WiseCORP, WiseHOME, WG RESCO and WG STaaS/VPP Pilot S checklists	ite details 42
	3.3.2 WiseEVP Pilot Site details checklist	61
3.4	Crevillent	64
	3.4.1 WG Cockpit Pilot Site details checklists	64
	3.4.2 WiseCOOP, WiseCORP, WiseHOME Pilot Site details checklists	66
	3.4.3 WiseEVP Pilot Site details checklist	73
3.5	Kythnos	75
	3.5.1 WG Cockpit Pilot Site details checklists	75
	3.5.2 WiseCORP and WG STaaS VPP Pilot Site details checklists	78
	3.5.3 WiseEVP Pilot Site details checklist	80
4	UPCOMING SYSTEMS AND DATA	82
4.1	Mesogia	82
4.2	Terni	82
4.3	Flanders	82
4.4	Crevilient	82
4.5	Kytnios	00
5	PLANNING AND TIMELINE OF THE INTEGRATION AND DEPLOYMENT ACTIVITIES	83
5.1	Integrated lab-Testing Activities	83
5.2	Preliminary Deployment	84
5.3	Final Deployment	84
6	CONCLUSIONS	89
7	REFERENCES AND ACRONYMS	89





7.1	References	89
7.2	Acronyms	89







List of Figures

Figure 1 – HL-UC 1	14
Figure 2 – HL-UC 2	15
Figure 3 – HL-UC 3	16
Figure 4 – HL-UC 4	17
Figure 5 – HL-UC 5	18
Figure 6 – HL-UC 6	19
Figure 7 – HL-UC 7	20
Figure 8 – Timeline for integrated lab-testing activities.	86
Figure 9 – Timeline for preliminary deployment activities	87
Figure 10 – Timeline for final deployment activities.	88







List of Tables

Table 1 – Tools to be tested in each Pilot Site	8
Table 2 – Tools to be tested in each Pilot Site	13
Table 3 – Acronyms list	89







EXECUTIVE SUMMARY

As explained in previous deliverables, WiseGRID will provide a set of 9 technological solutions which will aid to the widespread of the Smart Grids in Europe. It is necessary to understand the functionalities and the behaviour of all the tools in order to have an overview of which kind of Use Cases can be tested.

- **WG IOP:** It is a scalable, secure and open ICT platform, with interoperable interfaces, for real-time monitoring and decentralized control to support effective operation of the energy network.
- WG Cockpit: It is the WiseGRID technological product targeting DSOs and micro grid operators, allowing them to control, manage and monitor their own network, using flexibility to improve stability and security of their network.
- WiseCORP: It is the solution targeting businesses, industries, ESCOs and public facility consumers and prosumers, with the objective of providing them with the necessary mechanisms to become smarter energy players.
- WiseCOOP: It is the WiseGRID technological solution targeting aggregators of consumers and prosumers particularly focused on domestic and small businesses.
- **WiseHOME:** It is the tool of the WiseGRID framework that serves as the interface with the residential electricity consumer or prosumer.
- **WiseEVP:** It is the WiseGRID technological solution for vehicle-sharing companies or EV fleet managers and EVSE infrastructure operators.
- WG FastV2G: It is an innovative charging station that allows feeding electricity back into the grid from the EV battery.
- WG STaaS/VPP: It is the technological solution targeting aggregators with a portfolio based on distributed generation and storage assets.
- WG RESCO: This tool aims at supporting the RESCOs to manage the relationship with their customers and the provision of energy from renewable energy sources to consumers (households/businesses) not owning nor maintaining the respective equipment.

All these tools will be tested (following different scenarios or Use Cases) in the 5 Pilot Sites of WiseGRID. Each Pilot Site, according to their own characteristics, current infrastructure, needs and preferences have declared their intention of which tools will be tested in their premises. These choices can be seen in the following table. As the WG IOP is mandatory in order to assure the communication between all the tools and will be actually used in all the testing scenarios, it is out of this table.

	WiseCORP	WiseHOME	WiseEVP	WG FAST V2G	WG STAAS/VPP	WG COCKPIT	WG RESCO	WiseCOOP
Crevillent	Х	Х	Х	Х		X		Х
Terni	Х		Х		Х	X	Х	
Flanders	Х	Х	Х		Х		Х	Х
Mesogia	Х	Х				X		Х
Kythnos	Х		Х		Х	Х		

Table 1 – Tools to be tested in each Pilot Site

In order to better deploy the WiseGRID products in the respective demo sites, a planning and timeline has been created. The timeline follows the basic milestones of the WiseGRID project. These demonstration activities have been divided into three different stages:





Integrated Lab-Testing activities

It is a task that mainly refers to the tool developers of the consortium and its main scope is to test and evaluate the performance and interoperability of the WiseGRID tools in an integrated laboratory environment, as well as to refine them so as to be ready for the final deployment period.

Preliminary Deployment

The scope of this activity is, on the one hand, to give a feedback to the tool developers for the performance of the deployed tools at real world conditions and on the other hand, to activate the Pilot Sites so as to prepare their infrastructure before the final deployment.

Final Deployment

Both the Pilot Site leaders and the tool developers with the experience gained from the preliminary deployment will deploy and evaluate the operation of all the WG tools (as agreed per Pilot Site) with final goal the preparation for the demonstration activities that follow.







1 INTRODUCTION

1.1 PURPOSE OF THE DOCUMENT

The present document aims to describe and explain the results acquired from the Tasks 14.1 "Analysis of the Demo sites technical data" and 15.1" Demonstration activities planning". These tasks mainly deal with the description of the current infrastructure available in the Pilot Sites for WiseGRID purposes. In addition, it includes a planning for the deployment of the different WiseGRID tools taking into account which scenarios will be tested in the respective Pilot Sites.

1.2 SCOPE OF THE DOCUMENT

The extent of this deliverable is focused on the current infrastructure, characteristics, needs and preferences of the Pilot Sites that will be involved in the demonstration of the WiseGRID tools. The work performed in this deliverable has included the Pilot Sites as the core of all the sections in order to maximize the impact of the tools.

This deliverable will serve as a starting point for the wholes WP14 "Integration and deployment of Wise-GRID ecosystem" and WP15 "Large scale demonstration activities of the integrated WiseGRID ecosystem" providing the guidelines that will aid to the entire demonstration phase of the project.

1.3 STRUCTURE OF THE DOCUMENT

Apart from this introductory section, the current document is structured as follows:

Firstly, the 9 technological tools that WiseGRID is developing are explained. This part is the basis for the understanding of the Use cases (already defined in D2.1 "WiseGRID requirements, use cases and Pilot Sites analysis") that will be tested in each Pilot Site according to their preferences and characteristics.

Following that section, the document shows the different systems and devices already available in the Pilot Sites that will help the reader to understand in which conditions the tools will be deployed.

Next to that, the requirements of extra infrastructure are explained in order to show which are the currently missing systems for the optimal deployment of the tools.

Having in mind the previous information, the document also explains the expected planning and timeline for the most suitable deployment and demonstration of the tools.

Finally, the document ends with a brief summary and the exposition of the main conclusions that can be extracted from the whole document.





2 DESCRIPTION OF THE WISEGRID TOOLS AND USE CASES TO BE TESTED IN EACH PILOT SITE

As explained in previous deliverables, WiseGRID will provide a set of 9 technological solutions which will aid to the widespread of the Smart Grids in Europe. It is necessary to understand the functionalities and the behaviour of all the tools in order to have an overview of which kind of Use Cases can be tested.

2.1 WISEGRID TOOLS

2.1.1 WG IOP

The WiseGRID Interoperable Platform (WG IOP) is a scalable, secure and open ICT platform, with interoperable interfaces, for real-time monitoring and decentralized control to support effective operation of the energy network. The objective of the platform is to manage and process the heterogeneous and massive data streams coming from the distributed energy infrastructure deployed, acting as a platform for the intercommunication of the other WiseGRID tools. This platform will enable new services and reduce ICT costs for prosumers and smaller players, whilst it will facilitate cross-network and cross-entity interoperability.

It is possible to find further information of this tool in D4.2 "WiseGRID interoperable Integrated Process (WG IOP)".

2.1.2 WG Cockpit

WG Cockpit is the WiseGRID technological product targeting DSOs and micro grid operators, allowing them to control, manage and monitor their own network, using flexibility to improve stability and security of their network.

The main purpose of the WG Cockpit is to enable grid operators to manage the fundamental changes that distribution grids are facing nowadays, some remarkable ones of those being the transition towards a grid with high penetration of distributed renewable energy resources and the presence of additional significant loads coming from EVs among others. In addition, this particular outcome of the project aims at approaching the benefits that new technologies (such as big data or unbundled smart meters) and algorithms (such as state estimation or fault detection) bring to the operation of the grid. Finally, since one of the objectives of the project is the empowerment of the citizens in the energy field, the WG Cockpit will also demonstrate how that empowerment can be beneficial for several actors – including DSOs -, and how the whole ecosystem of actors can contribute to reach an environmentally and economically sustainable energy system.

It is possible to find further information of this tool in D13.1 "WiseGRID Cockpit Design".

2.1.3 WiseCORP

WiseCORP is the WiseGRID technological solution targeting businesses, industries, ESCOs and public facility consumers and prosumers, with the objective of providing them with the necessary mechanisms to become smarter energy players. By means of energy usage monitoring and analysis, proper information can be given to facility managers helping them to reduce energy costs and environmental impact.

A key factor towards achieving these objectives is the proper retrieval and analysis of energy usage data, and the visualization of meaningful information extracted from it.

It is possible to find further information of this tool in D7.1 "WiseCOOP and WiseCORP Apps Design".

2.1.4 WiseCOOP

WiseCOOP is the WiseGRID technological solution targeting aggregators of consumers and prosumers - particularly focused on domestic and small businesses -, supporting them in their roles of energy retailers, local communities and cooperatives – which may have different objectives. The main goal of this solution is helping consumers and prosumers work together in order to achieve better energy deals while relieving them from administrative procedures and cumbersome research.





This tool will be the core of the WiseGRID Demand Response Framework and the back-end of the WiseHOME tool.

It is possible to find further information of this tool in D7.1 "WiseCOOP and WiseCORP Apps Design".

2.1.5 WiseHOME

The WiseHOME app is the tool of the WiseGRID framework that serves as the interface with the residential electricity consumer or prosumer. Its initial goal is to provide a deep and comprehensive understanding of the energy consumption of the household to the user, in order to raise awareness about how energy is consumed, e.g. its time profile, what is the impact on total electricity intake from the grid, etc. In addition to this, WiseHOME will also inform the user about the state and performance of other assets he may have in the home, such as local generation, stationary batteries or EVs for instance.

It is possible to find further information of this tool in D11.1 "WiseHOME App Design".

2.1.6 WiseEVP

WiseEVP is the WiseGRID technological solution for vehicle-sharing companies or EV fleet managers and EVSE (Electric Vehicle Supply Equipment) infrastructure operators in order to allow them to optimize the activities related with smart charging and discharging of the EVs including V2G (vehicle to grid, energy injection in the distribution network) and V2B (vehicle to building). Moreover, the EV companies will have an overview of the current status of their EV fleet and Charging Stations.

It is possible to find further information of this tool in D9.1 "WiseEVP Design".

2.1.7 WG Fast V2G

WiseGRID FastV2G is an EVSE (Electric Vehicle Supply Equipment) which is able to:

- Perform a fast DC charging session.
- Inject electricity from the EV's battery to the network (V2G functionality).
- Perform a dynamic charging session (power modulation) in both directions: G2V and V2G.
- Receive "charging orders" from a hierarchically superior component.
- Send performance information to a hierarchically superior component.

The main objective of FastV2G is to provide auxiliary services to help in the distribution network operation and to maximize renewable resources integration, by providing:

- regulation services,
- spinning reserves,
- peak-shaving capacity in order to flatten out the demand curve.

It is possible to find further information of this tool in D8.2 "WiseGRID FastV2G and other optimized storage solutions".

2.1.8 WG STaaS/VPP

WG StaaS/VPP is the WiseGRID technological solution targeting aggregators with a portfolio based on distributed generation and storage assets. The main goal of this tool is to help consumers and prosumers (be them households or corporates) to be aggregated and offer to the market their unused storage capacity as well as spare generation in the form of a VPP.

It is possible to find further information of this tool in D6.2 "Storage as a service and Innovative optimized solutions".





2.1.9 WG RESCO

This tool aims at supporting the RESCOs to manage the relationship with their customers and the provision of energy from renewable energy sources to consumers (households/businesses) not owning nor maintaining the respective equipment. Since the generation equipment will be owned, serviced and operated by the RESCO itself, the tool will also support the maintenance management of those assets and the provision of the produced energy to the market. The Final goal is to increase the share of renewable distributed resources by supporting a business model which will encourage the wide adoption of those technologies.

It is possible to find further information of this tool in D12.2 "RESCO services and Advanced models for smartening the distribution grid".

2.2 TOOLS AND USE CASES TO BE TESTED IN EACH PILOT SITE

2.2.1 Tools

During the last months, the Pilot Site leaders completed the final list of the WiseGRID tools which will be tested in their respective Pilot Sites. These tools are coherent according to their business strategy, current infrastructure and future development plans. In Table 2, the tools to be deployed in each Pilot Site are shown. As the WG IOP is mandatory in order to assure the communication between all the tools, it is out of this table.

	Table 2 Tools to be tested in each Fligt Site								
	WiseCORP	WiseHOME	WiseEVP	WG FAST V2G	WG STAAS/VPP	WG COCKPIT	WG RESCO	WiseCOOP	
Crevillent	Х	Х	Х	Х		Х		Х	
Terni	Х		Х		Х	Х	Х		
Flanders	Х	Х	Х		Х		Х	Х	
Mesogia	Х	Х				Х		Х	
Kythnos	Х		Х		Х	Х			

Table 2 – Tools to be tested in each Pilot Site

All the WiseGRID tools (except WG FastV2G) will be widely covered by at least 2 different Pilot Sites and the project will have the opportunity to properly assess the performance of each tool.

In Section 3, it is possible to see the systems and technologies already available in each Pilot Site in order to facilitate the deployment and testing of the abovementioned tools.

2.2.2 Use Cases

In the context of the WP2 "WiseGRID Use cases, requirements and KPIs definition", there was defined a list of Primary (PUC) and Secondary (SUC) Use Cases to be tested in the demonstration phase of the project. At that step, the Pilot Sites ranked their interest on testing each PUC and SUC. However, at this stage, the Pilot Sites have been more specific in declaring their intention for testing the Use Cases. In the final list, which can be seen in the following figures, there are 6 SUCs (from the initial total number of 102) and 1 PUC (from the initial total number of 27) that finally will not be tested in WiseGRID (indicated in red). As the amount of Use Cases rejected is almost negligible and none of them was listed as of "High Priority", this will not affect the final results of the project.

This Use Cases' list is coherent with the tools which will be tested in each Pilot Site, as indicated in Section 2.2.1.





		PILOT SITES IMPLEMENTATION					
WiseGRID USE CASES INVENTORY	UC priority	ENER	ECO	ASM	HEDNO	AEA	
			(Ghent)	(Terni)	(Mesogia)	(Kythnos)	
HL-UC 1 DISTRIBUTED RES INTEGRATION IN THE GRID (CRE)							
1 HL-UC 1_PUC_1_Network monitoring	High	Y	Ν	Y	Y	Y	
2 HL-UC 1_SUC_1.1_Data collection from the RES and critical network sections	High	Y	Ν	Y	Y	Y	
3 HL-UC 1_SUC_1.2_Forecast of RES production, consumption and of total power flow in critical sections	High	Y	N	Y	Y	Y	
4 HL-UC 1_SUC_1.3_KPI management	High	Y	N	Y	Y	Y	
5 HL-UC 1_SUC_1.4_Big data storage analysis	High	Y	N	Y	Y	Y	
6 HL-UC 1_PUC_2_Control strategies for reducing RES curtailment	High	Y	Ν	Y	Y	Y	
7 HL-UC 1_SUC_2.1_Reduce RES curtailment by encouraging neighbourhood transactions and real-time consumption	High	Y	N	Y	Y	Ν	
8 HL-UC 1_SUC_2.2_Reduce RES curtailment by using grid storage distributed means	High	Ν	N	Y	Ν	Y	
9 HL-UC 1_SUC_2.3_Providing DSO curtailment warnings service to allow RES strategies	High	Y	N	Y	Y	Y	
10 HL-UC 1_SUC_2.4_Methods for reducing RES curtailment in island mode	Low	Y	N	Y	Ν	Ν	
11 HL-UC 1_PUC_3_Voltage support and congestion management	High	Y	Ν	Y	Y	Ν	
12 HL-UC 1_SUC_3.1_Provide local U control through P-Q flexibility of RES inverters (Centralized)	High	Y	Ν	Y	MAYBE	Ν	
13 HL-UC 1_SUC_3.2_Provide local U control through P-Q flexibility of RES inverters (Decentralized)	Medium	Y	Ν	Y	MAYBE	Ν	
14 HL-UC 1_SUC_3.3_Improve voltage symmetry between the phases	Low	Y	Ν	Y	Ν	Ν	
15 HL-UC 1_PUC_4_Grid planning analysis	Low	Y	Ν	Υ	Ν	Ν	
16 HL-UC 1_SUC_4.1_EV charge points planning analysis	Low	Y	Ν	Υ	Ν	Ν	
17 HL-UC 1_SUC_4.2_Grid storage planning analysis	Low	Y	Ν	Υ	Ν	Ν	
18 HL-UC 1_PUC_5_Promote RES via RESCO companies	Medium	Y	Y	Υ	Ν	Ν	
19 HL-UC 1_SUC_5.1_RESCO asset inventory, control and maintenance	Medium	Y	Y	Υ	Ν	Ν	
20 HL-UC 1_SUC_5.2_Monitor domestic RES production	Medium	Y	Y	Υ	Ν	Ν	
21 HL-UC 1_SUC_5.3_Monitor domestic clients consumption	Medium	Y	Y	Y	N	N	
22 HL-UC 1_SUC_5.4_Manage energy selling	Medium	Y	Y	Y	N	Ν	
23 HL-UC 1_SUC_5.5_Energy cost management	Medium	Y	Y	Y	N	Ν	

Figure 1 – HL-UC 1





WiseGRID USE CASES INVENTORY			PILOT SITES IMPLEMENTATION						
		UC priority	ENER	ECO	ASM	HEDNO	AEA		
	partiter		(Creville	(Ghent)	(Terni)	(Mesogia)	(Kythnos)		
HL-UC 2 DECENTRALIZED GRID CONTROL AUTOMATION (ICCS)									
24 HL-UC 2_PUC_1_Distribution network real-time monitoring	ETRA	High	Y	N	Y	Y	Y		
25 HL-UC 2_SUC_1.1_Monitoring grid through Unbundled Smart Meters	ETRA	High	Y	Ν	Y	Y	N		
26 HL-UC 2_SUC_1.2_Data concentration	ETRA	High	Y	N	Y	Y	N		
27 HL-UC 2_SUC_1.3_Monitoring power quality in the grid	ETRA	High	Y	N	Y	Y	Y		
28 HL-UC 2_SUC_1.4_Fault detection and identification	ETRA	High	Y	N	Y	Y	N		
29 HL-UC 2_SUC_1.5_Asset management	ETRA	High	Y	N	Y	Y	Y		
30 HL-UC 2_PUC_2_Real-time distribution system awareness	ICCS	High	Y	N	Y	Y	Y		
31 HL-UC 2_SUC_2.1_RES and load forecasting	ICCS	High	Y	Ν	Y	Y	Y		
32 HL-UC 2_SUC_2.2_Topology processor	ICCS	Medium	Y	Ν	Y	Y	Y		
33 HL-UC 2_SUC_2.3_Network observability analysis	ICCS	High	Y	Ν	Υ	Y	Y		
34 HL-UC 2_SUC_2.4_Load flow calculation	ICCS	High	Y	Ν	Y	Y	Y		
35 HL-UC 2_SUC_2.5_State estimation	ICCS	High	Y	Ν	Y	Y	Y		
36 HL-UC 2_SUC_2.6_Bad data detection, identification and replacement	ICCS	High	Y	Ν	Y	Y	Y		
37 HL-UC 2_PUC_3_Grid control	ICCS	High	Y	Ν	Y	Y	Y		
38 HL-UC 2_SUC_3.1_Load control	ICCS	High	Y	Ν	Y	Y	Y		
39 HL-UC 2_SUC_3.2_DR as a service to the grid	ICCS	High	Y	Ν	Y	Y	Y		
40 HL-UC 2_SUC_3.3_Optimization algorithm	ICCS	High	Y	N	Y	Y	Y		
41 HL-UC 2_SUC_3.4_Reconfiguration	ICCS	Medium	Y	N	Y	Y	N		
42 HL-UC 2_SUC_3.5_Islanding procedures for the local grid	ICCS	Low	Y	N	Y	N	N		
43 HL-UC 2_SUC_3.6_Cold ironing	ICCS	Medium	N	N	N	N	Y (Simulation)		

Figure 2 – HL-UC 2





		PILOT SITES IMPLEMENTATION					
WiseGRID USE CASES INVENTORY	UC priority	ENER	ECO	ASM	HEDNO	AEA	
		(Creville	(Ghent)	(Terni)	(Mesogia)	(Kythnos)	
HL-UC 3 e-MOBILITY INTEGRATION IN THE GRID WITH V2G (ITE)							
44 HL-UC 3_PUC_1_EVSE and EV fleet monitoring	High	Y	Y	Y	N	Y	
45 HL-UC 3_SUC_1.1_Data collection from EVSE	High	Υ	Y	Y	N	Y	
46 HL-UC 3_SUC_1.2_Data collection from EVs	High	Y	Y	Y	N	Y	
47 HL-UC 3_PUC_2_Interaction of the user with EVSE	Medium	Y	Y	Y	N	Y	
48 HL-UC 3_SUC_2.1_Users' authentication	Medium	Y	Y	Y	N	Y	
49 HL-UC 3_SUC_2.2_Charging session request	Medium	Y	N	Y	N	Y	
50 HL-UC 3_SUC_2.3_Charging session booking	Medium	Y	N	Y	N	Y	
51 HL-UC 3_PUC_3_EV charging management	Medium	Y	Y	Y	N	Y	
52 HL-UC 3_SUC_3.1_EVSE network configuration	Medium	Y	Y	Y	N	Y	
53 HL-UC 3_SUC_3.2_EV load forecasting	Medium	Y	Y	Y	N	Y	
54 HL-UC 3_SUC_3.3_EV flexibility estimation	Medium	Y	N	Y	N	Y	
55 HL-UC 3_SUC_3.4_Reference charging load profile calculation	Medium	Y	Y	Y	N	Y	
56 HL-UC 3_SUC_3.5_Charging session schedule	High	Y	Y	Y	N	Y	
57 HL-UC 3_PUC_4_Interaction with the energy infrastructure	Medium	Y	Ν	Y	N	Y	
58 HL-UC 3_SUC_4.1_Charging reschedule to follow grid requests	Medium	Y	N	Y	N	Y	
59 HL-UC 3_SUC_4.2_Charging reschedule to maximise RES integration	High	Y	N	Y	N	N	
60 HL-UC 3_SUC_4.3_EV providing V2H services	Medium	Y	N	Y	N	N	

Figure 3 – HL-UC 3





			PILOT SITES IMPLEMENTATION					
	WiseGRID USE CASES INVENTORY	UC priority	ENER	ECO	ASM	HEDNO	AEA	
			(Creville	(Ghent)	(Terni)	(Mesogia)	(Kythnos)	
	HL-UC 4 BATTERY STORAGE INTEGRATION AT SUBSTATION AND PROSUMER LEVEL (AMP / VS)							
61	HL-UC 4_PUC_1_Batteries management at prosumer level	High	Ν	Y	Y	N	Y	
62	PHL-UC 4_SUC_1.1_Increase of self-consumption	High	N	Y	Y	N	Y	
63	BHL-UC 4_SUC_1.2_Time-of-use management	Medium	N	Y	Y	N	Y	
64	HL-UC 4_SUC_1.3_Peak Shaving	Medium	Ν	Y	Y	N	Y	
65	HL-UC 4_PUC_2_Batteries management at aggregator level (grid support)	Medium	Ν	Y	Ν	N	Y	
66	HL-UC 4_SUC_2.1_Batteries dispatch management	High	Ν	Υ	Ν	N	Y	
67	PHL-UC 4_SUC_2.2_Black start capabilities	Low	Ν	Y	Ν	N	Ν	
68	HL-UC 4_SUC_2.3_Power management for peak-shaving and load harmonization	Medium	Ν	Y	Ν	N	Ν	
69	HL-UC 4_SUC_2.4_Backup power for residential area	Low	Ν	N	Ν	N	Ν	
70	HL-UC 4_PUC_3_Ancillary services	Medium	Ν	Y	Y	N	Y	
71	LHL-UC 4_SUC_3.1_Market scheduling	High	Ν	Y	Y	N	Y	
72	PHL-UC 4_SUC_3.2_Combination of applications/services in the same storage system	Medium	Ν	Y	Y	N	Y	
73	HL-UC 4_SUC_3.3_Batteries automatic dispatch	Medium	Ν	Y	Y	N	Y	
74	HL-UC 4_PUC_4_Combination of battery storage systems	Medium	N	Y	N	N	Y	
75	HL-UC 4_SUC_4.1_Parameter configuration of storage systems	Medium	N	Y	N	N	Ŷ	
76	HL-UC 4_SUC_4.2_Priority list of units running	Medium	Ν	Y	N	N	Y	

Figure 4 – HL-UC 4





			PILOT SITES IMPLEMENTATION					
	WiseGRID USE CASES INVENTORY		ENER	ECO	ASM	HEDNO	AEA	
			(Creville	(Ghent)	(Terni)	(Mesogia)	(Kythnos)	
	HL-UC 5 COGENERATION INTEGRATION IN PUBLIC BUILDINGS/HOUSING (ICCS / EPA)							
7.	7 HL-UC 5_PUC_1_Thermal monitoring	Medium	Ν	Ν	Ν	Y	Ν	
78	8 HL-UC 5_SUC_1.1_Monitoring gas meters	Low	Ν	Ν	Ν	Y	Ν	
79	HL-UC 5_SUC_1.2_Monitoring CHP	Medium	N	Ν	Ν	Y	Ν	
80	OHL-UC 5_SUC_1.3_Monitoring buildings	Medium	Ν	N	Ν	Ν	Ν	
8.	1 HL-UC 5_PUC_2_Cogeneration and HVAC management	Medium	Ν	N	Ν	Y	Ν	
82	2 HL-UC 5_SUC_2.1_Forecasting thermal needs	Medium	Ν	N	Ν	Y	Ν	
83	3 HL-UC 5_SUC_2.2_Real time control set-points	Medium	Ν	N	Ν	Y	Ν	
84	4 HL-UC 5_SUC_2.3_Control devices	Medium	Ν	N	Ν	Y	Ν	
8	SHL-UC 5_SUC_2.4_Alarm management	Medium	Ν	N	Ν	Y	Ν	
86	6 HL-UC 5_PUC_3_Comfort-based demand flexibility models	Medium	Ν	Ν	Ν	Y	Ν	
87	HL-UC 5_SUC_3.1_Thermal model of households	Medium	Ν	Ν	N	Ν	Ν	
88	8 HL-UC 5_SUC_3.2_Thermal model of building	Medium	Ν	Ν	N	Y	Ν	
89	9 HL-UC 5_SUC_3.3_Thermal flexibility modeling	Medium	Ν	Ν	Ν	Y	Ν	
90	OHL-UC 5_PUC_4_Cogeneration and HVAC optimisation	Medium	Ν	Ν	N	Ν	Ν	
93	1 HL-UC 5_SUC_4.1_VPP participation	Low	Ν	Ν	N	Ν	Ν	
92	2 HL-UC 5_SUC_4.2_Provision of ancillary services	Medium	N	N	N	N	N	
93	3 HL-UC 5_SUC_4.3_System optimisation	Medium	N	N	N	N	N	

Figure 5 – HL-UC 5





		PILOT SITES IMPLEMENTATION					
WiseGRID USE CASES INVENTORY	UC priority	ENER	ECO	ASM	HEDNO	AEA	
		(Creville	(Ghent)	(Terni)	(Mesogia)	(Kythnos)	
HL-UC 6 VPP TECHNICAL AND ECONOMIC FEASIBILITY (ENG)							
94 HL-UC 6_PUC_1_VPP monitoring and management	High	N	Y	Y	Ν	N	
95 HL-UC 6_SUC_1.1_Resource metering	High	N	Y	Y	Ν	N	
96 HL-UC 6_SUC_1.2_VPP RES forecast	High	N	Y	Y	Ν	N	
97 HL-UC 6_SUC_1.3_VPP flexibility forecast	High	N	Y	Y	Ν	N	
98 HL-UC 6_SUC_1.4_Strategies definition	Medium	Ν	Y	Y	Ν	N	
99 HL-UC 6_PUC_2_VPP market participation	Medium	Ν	Y	Y	Ν	N	
100 HL-UC 6_SUC_2.1_VPP market participation and bid calculation	Medium	Ν	Y	Y	Ν	N	
101 HL-UC 6_SUC_2.2_VPP ancillary market participation and bid calculation	Medium	Ν	Y	Y	Ν	N	
102 HL-UC 6_SUC_2.3_VPP unit scheduling	Medium	Ν	Y	Y	Ν	N	
103 HL-UC 6_PUC_3_VPP Real time control	High	Ν	Y	Y	Ν	Y	
104 HL-UC 6_SUC_3.1_Real time flexibility calculation	Medium	Ν	Y	Y	Ν	Y	
105 HL-UC 6_SUC_3.2_VPP implementation of ancillary services	Medium	Ν	Y	Y	Ν	Y	
106 HL-UC 6_SUC_3.3_Real time decision making	High	Ν	Y	Y	Ν	Y	
107 HL-UC 6_PUC_4_VPP users relationship management	Low	Ν	Y	Υ	Ν	N	
108 HL-UC 6_SUC_4.1_Manage contractual issues	Low	N	Y	Y	N	N	
109 HL-UC 6_SUC_4.2_Define and manage member compensation	Low	N	Y	Y	Ν	N	
110 HL-UC 6_SUC_4.3_DSM and DR mechanisms	High	N	Y	Υ	Ν	N	

Figure 6 – HL-UC 6





			PILOT SITES IMPLEMENTATION						
	WiseGRID USE CASES INVENTORY	UC priority	ENER	ECO	ASM	HEDNO	AEA		
			(Creville	(Ghent)	(Teml)	(Mesogla)	(Kythnos)		
	HL-UC 7 CITIZENS EMPOWERMENT IN ENERGY MARKET AND REDUCTION OF ENERGY POVERTY (HYP)								
113	1 HL-UC 7_PUC_1_Dynamic management of demand side assets in tertiary sector	High	Y	Y	Y	Y	Y		
112	2 HL-UC 7_SUC_1.1_Monitor energy demand	High	Y	Y	Y	Y	Y		
113	3 HL-UC 7_SUC_1.2_Enriched information visualization	High	Y	Y	Y	Y	N		
11/	4 HL-UC 7_SUC_1.3_integration with DR mechanisms	High	Y	Y	Y	MAYBE	Y		
115	SHL-UC 7_SUC_1.4_Net metering & self consumption	Medium	Y	Y	Y	N	N		
110	HL-UC 7_SUC_1.5_Energy cost management for large infrastructures	Medium	Y	Y	Y	SIMULATION	N		
113	7 HL-UC 7_PUC_Z_Dynamic aggregation of distributed energy assets and active participation into energy market	High	Y	Y	N	Y	N		
112	8 HL-UC 7_SUC_2.1_Enriched information visualization	High	Y	Y	N	Y	N		
119	HL-UC 7_SUC_2.2_Portfolio profiling & analytics	High	Y	Y	N	Y	N		
120	HL-UC 7_SUC_2.3_Portfolio demand forecasting for wholesale energy trading	High	Y	Y	N	Y	N		
12	1 HL-UC 7_SUC_2.4_Billing services	Medium	Y	Y	N	Y	N		
122	2 HL-UC 7_SUC_2.5_Energy cost management and optimization	Medium	Y	Y	N	Y	N		
123	3 HL-UC 7_SUC_2.6_A utom ated DSM strategies activation through direct load control	Medium	N	Y	N	Y	N		
124	HL-UC 7_SUC_2.7_Manual DSM strategies activation	High	N	Y	N	Y	N		
125	SHL-UC 7_PUC_3_Clients engagement for active market participation	High	Y	Y	N	Y	N		
126	HL-UC 7_SUC_3.1_Enriched information visualization for energy monitoring	High	Y	Y	N	Y	N		
123	7 HL-UC 7_SUC_3.2_Social network collaboration and comparisons with peers	Low	Y	Y	N	Y	N		
122	BHL-UC 7_SUC_3.3_Participation in DR programs	High	Y	Y	N	Y	N		
129	HL-UC 7_SUC_3.4_Residential net metering & self consumption	Medium	Y	Y	N	N	N		

Figure 7 – HL-UC 7





3 EXISTING SYSTEMS AND INFRASTRUCTURE

Each Pilot Site has different technologies in place and it is necessary to know them in order to better plan the deployment activities. The current infrastructure will allow the tool developers to also refine the tools according to the needs and opportunities of these systems. This section will provide a short description of each Pilot Site (for better understanding of their activities and businesses) and a summary of their current systems. For that last purpose, the coordinators of the Pilot Sites have completed some questionnaires with the required details about their current systems in place. Although there is a lot of information in this section, by the date of the submission of this deliverable there is still some minor info to be defined in these questionnaires. However, this is not a shortcoming for the planning of the deployment and demonstration phase of the project due to the consortium has the main information for starting their deployment activities.

Further descriptions about all the Pilot Sites can be found in D2.1" WiseGRID requirements, Use cases and Pilot Sites analysis".

3.1 MESOGIA

This Pilot Site is located in the area of Mesogia at the south-eastern part of Attica, near Athens. Mesogia area includes the municipalities of Koropi, Lavrio, N. Makri and the interconnected islands of Kea, Andros and Tinos. The main coordinator of this Pilot Site is the Hellenic Electricity Distribution Network Operator (HEDDO) in charge of operating, maintaining and evolving the Distribution Grid.

The Mesogia area is considered ideal for demonstration purposes since: a) it combines parts of mainland and interconnected islands, which is an interesting mixture of locations, systems and infrastructure to be studied, b) provides a mix of rural, urban and suburban areas, c) consists of a customer mix including: households, small, medium and large industries, d) has high RES penetration of various types and e) is close to the capital. Some of the buildings used for the demo purposes are described in the following checklists for the respective tools.

3.1.1 WG Cockpit Pilot Site details checklists

3.1.1.1 Set-up		
Information required		
Database of distribution grid assets, including GIS in	ormation (geojson, postgis)	Х
Single-wire diagrams of distribution grid (including trotechnical assets,) – MV and LV (PSSE raw,)	topology, line characterization, impedances, elec-	Х
3.1.1.2 Integration with DSOs syste	ms	
SCADA		

Manufacturer	EFACEC
Model	
Will it be available for monitoring?	Yes X No □





Type of monitored signals (node voltages, line currents, switches and pro- tective device states,)		
Frequency of data acquisition		
Approx. amount of monitored signals in demo site		
Will it be available for controlling field assets (self-healing features)?	Yes No 🗆 TBD (To Be Defined)	
Which protocol is available for integration with third parties?		

AMI/AMR	
Manufacturer	ITF-EDV for the first 200 smart meters
Model	Basis 01x/C10 ZFA/200-F5/250,000/C10 for the first 200 smart meters SLAM/SMX for the last 200 smart meters
Approx. number of smart meters in demo site	400
Communication with Smart Meters (GPRS, PLC, etc.)	GSM/GPRS for the first 200 smart meters Wifi/ethernet for the last 200 smart meters
Frequency of readouts from smart meters	Frequency of readings from smart meters (communications GSM/GPRS): 1/3days Frequency of readings from smart meters (communications Wifi/ethernet): adjustable, possible near real-time monitoring
Frequency of readouts from concen- trators	No PLC communications for data readouts via concentrators.
Which protocol is available for inte- gration with third parties?	DLMS Cosem

3.1.1.3 Field devices

Medium voltage grid	
Which elements are you currently monitoring with your SCADA (e.g. Fault Passage Indicators, protective relays, transformers)?	TBD
Which elements are you able to control from your SCADA (switches)?	TBD

3.1.1.4 RES and Electric Vehicles





RES	
Which RES units are present in your distribution grid? Please provide details (number of units, types, average peak power, ratio compared to overall demand)	5 Wind farms of total inst. power 5,150.00 kW 280 PV of total inst. power 48,822.88 kW 40 PV net metering of total inst. power 545.84 kW 1457 Rooftop PV of total inst. power 12,442.68 kW Capacity factor for wind farms: 30% Electricity production of Rooftop PV: 1400 kWh/ kWinstalled Electricity production of PV: 1500 kWh/ kWinstalled
Are you currently monitoring produc- tion of those units? How? (SCADA, AMI,Protocols)	Most of them are telemetered (except for rooftop PV).
Are you in position of controlling RES units? (production curtailment, power factor) How? (direct control, signal- ling to third party)	RTUs and SCADA/DMS are expected to be used in the future for big RES plants (above 500kW). Right now, there are no RTUs for the telecontrol of the existing RES units connected to the distribution network of Mesogia Area. The only control applied to them is their disconnection in case of serious danger for the safety and balance of the grid; this can be done either manually, when the RES is connected to an individual line to the substation, or automatically through the RTU of the substation line. For the demo project, the virtual environment of SCADA/DMS will be used to simulate the control of RES units.

Electric Vehicles	
Are there electric vehicle charging stations deployed in your distribution grid? Please provide details (number of units, demand profile, ratio compared to overall demand)	Yes, installed for the European project SHAR-Q.
Are you currently monitoring demand of those units? How? (SCADA, AMI, Protocols)	We monitor EV charging sessions via a custom platform (currently under devel- opment), using OCPP.
Are you in position of controlling the operation of the charging points? (start/stop operations, limit supply) How? (direct control, signalling to third party)	Yes, via a custom platform (currently un- der development), using OCPP.

3.1.2 WiseCOOP, WiseCORP, WiseHOME, Pilot Site details checklists

3.1.2.1 Aggregator information





Information required

Approx. amount of custom- ers/members of cooperative/DSO	400 of the customers connected to the network will participate in the demo site. The majority will be deployed in the area of Mesogia.
Please provide database with details on customers/members (location, pro- file) – <u>No personal information re-</u> guired	X
Existing customer types	Commercial/tertiary (LV) Commercial/tertiary (MV) X (potentially metering data from commercial/tertiary (MV)) Residential (LV) X Others X (Public Buildings)
Number of customers/members equipped with smart meters	400 smart meters
Frequency of readings from smart me- ters	Frequency of readings from smart meters (communications GSM/GPRS): 1/3days
When do the smart meter readings become available to you?	Meter readings collected by the AMR/AMI systems will become available to us once every 3 days. For the demo project though, a common for ICCS and HEDNO simulated AMR/AMI system will collect the meter readings, corresponding to the exact previous week.

3.1.2.2 Tariff information

Information required	
Provide a list the retailers that offer tariffs that can be applied to your buildings	 Public Power Corporation S.A. ELPEDISON S.A HERON GREEN S.A. VOLTERRA S.A PROTERGIA_THERM S.A. WATT AND VOLT S.A. NRG TRADING HOUSE S.A. VOLTON S.A. ELTA HELLENIC POST S.A. KEN S.A ZeniΘ





What types of time-of-use tar- iffs are there (single period, 2 periods, 3 periods, etc.)	2 periods
For time-of-use tariffs, what is the minimum reading frequen- cy for consumption (1 hour, 15 minutes, etc.)	The minimum reading frequency for consumption is 1/hour.
	There are three categories of tariffs: residential, business and large business MV.
Is there a differentiation of tar- iffs based on active power? Please provide information.	Business Tariffs are addressed to customers for commercial use, (offices, shops, warehouses, infirmaries, shopping centers, etc.), industrial use (workshops, craft industries, small industries, bakeries and other businesses) and general use (public areas, warehouses, parking spaces). There are three Business Tariffs for commercial and industrial use: $\Gamma 21$, $\Gamma 22$ and $\Gamma 23$. Business Tariffs $\Gamma 21$ & $\Gamma 22$ are differentiated according to active power.
	consumption and small capacity. More specifically, it is provided to units with installed capacity up to 25 kVA for use in offices, shops, public areas, workshops, small craft industries, etc. Business tariff Γ 22 is addressed to customers with high levels of consumption. It is provided to units with installed capacity from 25 kVA up to 250 kVA.
	Furthermore, there is a differentiation of Public Lighting Tariffs for the lighting of streets and squares (T-49, T α -49/1, F4) based on active power (<25kVA, >25kVA without calculation of reactive power, >25kVA with calculation of reactive power).
	Each supplier has its own tariffs addressing different customers, services, needs but in general the tariffs follow the main categorization scheme described above and here. Indicatively, here, we mention the different tariff schemes as they are categorized and characterized by the main electrical energy supplier in Greece, PPC.
Is there a differentiation of tar- iffs based on voltage? Please provide information.	 a. Residential Tariff b. Residential Night Tariff c. Large Family Tariff d. Social Residential Tariff 2. Business Tariffs (LV) a. Business Tariff Γ 21 b. Business Tariff Γ 22 c. Business Tariff Γ 23 d. Agricultural Tariff – Reduced Agricultural Tariff (T33/LV, T33A/LV and other low voltage agricultural tariffs) e. Public Lighting Tariffs (T-49, T-49/1, Γ4)





	3. Large Bus a. M b. M c. M d. M	iness MV Tariffs (MV) IV Tariff IV Tariff (High Coefficient Usage) IV Tariff (Low Coefficient Usage) IV Tariff - Agricultural -Reduced Agricultural Tariff	
	Tariffs addressed agricultural, busin	l to customers depend on energy use (residentia ess, public lighting, etc.).	ıl,
Are there any other types of differentiation and/or re- strictions that limit the selec- tion of a tariff plan? Please provide information.	In particular, the and invoices) is consumption with prices. So, the co increased price c while the consur reduced price. Th irrespective of cap	Business Tariff Γ 23, (as they are coded for PPC's tariff a tariff that includes two charging prices, that is, th in the 24-hour period is calculated using two differen nsumption within the peak period is charged with th ompared to the other Commercial Tariffs (Γ 21, Γ 22 nption within the off-peak period is charged with is tariff can be provided to all the business customer pacity.	fs ne nt ie ?), a rs
	Furthermore, the consumption and	re is a differentiation of Residential Tariffs based o single phase or 3-phase supply.	n
	Moreover, there on coefficient usa mum demand.	is a differentiation of Large Business MV Tariffs base ge, and particularly, consumption and measured max	ed (i-
Are dynamic price tariffs avail- able in your region or by your supplier? Is your building eligi- ble for them? Please provide information.	No		
Any other comments/remarks regarding tariff ruling in your country?			

3.1.2.3 Etaireia Dianomis Aeriou Attikis Headquarters

3.1.2.3.1 Building information

Information required	
Name of building	Etaireia Dianomis Aeriou Attikis Headquarters
Location (coordinates)	38.0690511, 23.7799473 // Leoforos Sofokli Venizelou 11, 14123 Lukovrisi, Athens
Structural information (e.g. surface, dimensions, floors, areas, etc.)	3 floors, dimensions: $31m \times 67m \times 19m$ (height), total area : $6100m^2$
Usage (e.g. purpose, occupants, working times)	office space, 07:00-18:00
Available equipment	
Sensors (please focus especially on occupancy and environmental sensors, e.g. temperature, humidity, luminance,	No X Yes \Box ; please, provide details:





IAQ, etc.)	
Controllable assets (please focus especially on energy hungry assets, e.g. HVAC, lighting, pool equipment, etc.)	No X Yes \Box ; please, provide details:
Local electricity generation (emphasis on RES)	No \Box Yes X ; please, provide details: 5 KWe CHP unit (currently being installed)
Storage (incl. Electric Vehicles)	No X Yes \Box ; please, provide details:
Smart meters/	No \Box Yes X
Power analysers	Gas Meter
Building Management System	No X Yes \Box ; please, provide details (e.g. about make, capabilities and connected assets):
Others	
Approx. building annual electricity consumption	1,080,000 kWh
Approx. annual electricity production (if RES)	-
Metering	
Are you metering particular areas/assets demand independently? (sub-metering)	No X Yes \Box ; please, provide details (e.g. how, which assets, their importance to building consumption, etc.):
Frequency of readouts	Hourly (after special request to the retail company)
Historical readouts available (historical traces of con- sumption is needed to calibrate/train models)	No Yes X; please, provide details: NG monthly consumption Electricity monthly consumption
Price history available	No \Box Yes X please, provide details: NG monthly price Electricity monthly price
Billing	
Current tariff plan	07:00-23:00 on working days: 0.06428 €/kWh. 23:00-07:00 on working days, during weekend and on holidays: 0.05062 €/kWh.
Current involvement in demand response pro- grammes	NO
Legal	
Who owns the building?	private owner





Is an agreement needed to access data for demo purposes?	No \Box Yes, owner consent is required \Box Yes, consent from building occupants is required X
Is an agreement needed to take actions over as- sets for demo purposes?	No Yes, owner consent is required Yes, consent and building occupants is re- quired X

3.1.2.3.2 Available controllable assets

Information required	
Manufacturer/Model	Not deter- mined
Available protocol for monitoring/control (please elaborate on how the asset setpoints or meas- urements can be accessed)	
Is it possible to capture the setpoints that users apply (e.g. temperature on thermostats or dim- ming levels)?	No Yes I do not know X
Controllability restrictions (technical, legal, contractual, comfort)	
Energy demand of asset – frequency of readouts	
When are the readouts available to you or to third parties?	
Are these readings personal/sensitive data according to European or national legislation?	No Yes I do not know X
Energy demand of asset – historical readouts available	Х





3.1.2.4 Small cottage for summer holidays

3.1.2.4.1 Building information

Information required	
Name of building	
Location (coordinates)	Meltemi seaside camping at Rafina (38.001466, 24.022994)
Structural information (e.g. surface, dimensions, floors, areas, etc.)	The 230 cottages are not bigger than 50m ² . Most of the houses are prefabricated; built in components (e.g. panels), modules (modular homes) or transportable sections (manufactured homes). Furthermore, light materials are used for the construction of each cottage and the use of concrete is limited. The typical house consists of 1 bedroom, 1 kitchen, 1 bathroom and 1 living room merged into the dining room for spacious reasons.
Usage (e.g. purpose, occupants, working times)	Small cottage used mostly for summer holidays. Due to the small size of each cottage, its electrical consumption is lower than that of an ordinary house in Greece. During the summer months, the demand is expected to be higher than the winter months because of the sum- mer holidays.
Available equipment	
Sensors (please focus especially on occupancy and environmental sensors, e.g. temperature, hu- midity, luminance, IAQ, etc.)	No Ves X; please, provide details: Temperature Sensors Humidity Sensors Energy Sensors
Controllable assets (please focus especially on energy hun- gry assets, e.g. HVAC, lighting, pool equipment, etc.)	 No □ Yes X; please, provide details: Water Heater (5 houses) Oven (1 house) A/C (1 house)
Local electricity generation (emphasis on RES)	 No Yes X please, provide details: 4.5 kW PV 3 WT (currently offline due to residents' complaints) 1 GenSet 40kVA
Storage (incl. Electric Vehicles)	No 🗌 Yes 🗔; please, provide details:
Smart meters/ Power analysers	No \Box Yes X; please, provide details (with emphasis on frequency of metering and when the data can become accessible to you or a third party): SMX developed for Nobelgrid project [1] and smart meters developed





No Yes X; please, provide details (e.g. about make, capabilities and connected assets): A total of ten (10) smart load controllers have been installed in ten (10) of the Meltemi cottages that provide remote measurements and control of various load types (e.g. water heater, A/C).
The Meltemi MV/LV substation is also equipped with energy meters that provide power quality measurements. The substation consists of 6 feeders that distribute the energy throughout the Meltemi camp. Smart meters have also been installed in all Meltemi cottages.
< 1,250 kWh
No X Yes : please, provide details (e.g. how, which assets, their importance to building consumption, etc.):
Frequency of readings from smart meters (communications GSM/GPRS): 1/3days
No 🗆 Yes X please, provide details:
No 🗌 Yes 🗔; please, provide details:
Citizens
No \Box Yes, owner consent is required X Yes, consent from owner and building occupants is required \Box





is an agreement needed to	No 🗆
take actions over assets for demo purposes?	Yes, owner consent is required ${f X}$
	Yes, consent from owner and building occupants is required \Box

3.1.2.4.2 Available sensing equipment

Information required	
Manufacturer/Model	
	Temperature Sensors
Sensor type (e.g. temperature, occupancy, IAQ, luminance, etc.)	 Humidity Sensors
	 Energy Sensors
Available protocol for monitoring/control (please elaborate on how the sensor readings can be accessed)	Modbus TCP/IP, SSH, Open- ADR
Sensor readings – frequency of readouts	min., 100ms
Are these readings personal/sensitive data according to European or na- tional legislation?	No 🗆 Yes 🗆
	I do not know 👗
Sensor readings – historical readouts available	

3.1.2.4.3 Available controllable assets

Information required	
Manufacturer/Model	
Available protocol for monitoring/control (please elaborate on how the asset setpoints or measurements can be accessed)	Modbus TCP/IP
Is it possible to capture the setpoints that users apply (e.g. temperature on thermostats or dimming levels)?	No 🗆 Yes 🗙 I do not know 🗔
Controllability restrictions (technical, legal, contrac- tual, comfort)	The device needs to be on and can only be turned off remotely, because controllable relay is in series with device switch.
Energy demand of asset – frequency of readouts	
When are the readouts available to you or to third	Real-time readouts





parties?	
Are these readings personal/sensitive data according to European or national legislation?	No 🗆 Yes X I do not know 🗆
Energy demand of asset – historical readouts availa- ble	No
3.1.2.5 Mesogia Household with CHP	

3.1.2.5 Mesogia Household with CHP

Information required		
Name of building	Mesogia Household with CHP	
Location (coordinates)	Mesogia	
Structural information (e.g. surface, dimensions, floors, areas, etc.)	2-floor house	
Usage (e.g. purpose, occupants, working times)	household	
Available equipment		
Sensors (please focus especially on occupancy and environmental sensors, e.g. temperature, humidity, luminance, IAQ, etc.)	No X Yes : please, provide details:	
Controllable assets (please focus especially on energy hungry assets, e.g. HVAC, lighting, pool equipment, etc.)	No X Yes \Box ; please, provide details:	
Local electricity generation (emphasis on RES)	No Yes X; please, provide details: 6 KWe/ 15 kWth CHP unit (purchased, to be installed) Vitobloc 200 EM-6/15 from Viessmann	
Storage (incl. Electric Vehicles)	No X Yes \Box ; please, provide details:	
Smart meters/ Power analysers	No Yes X please, provide details (with emphasis on frequency of metering and when the data can become accessible to you or a third party):	
Building Management System	No X Yes □; please, provide details (e.g. about make, capabilities and connected assets):	





	Others	
Approx	k. building annual electricity consumption	2,500 kWh
Approx	 annual electricity production (if RES) 	-
Meter	ing	
	Are you metering particular areas/assets demand independently? (sub-metering)	No X Yes ; please, provide details (e.g. how, which assets, their importance to building consumption, etc.):
	Frequency of readouts	Hourly (after special request to the retail company)
	Historical readouts available (historical traces of consumption is needed to calibrate/train models)	No Yes X; please, provide details: NG monthly consumption Electricity monthly consumption
	Price history available	No \Box Yes X please, provide details: NG monthly price Electricity monthly price
Billing		
	Current tariff plan	
	Current tariff plan Current involvement in demand response programmes	NO
Legal	Current tariff plan Current involvement in demand response programmes	NO
Legal	Current tariff plan Current involvement in demand response programmes Who owns the building?	NO private owner
Legal	Current tariff plan Current involvement in demand response programmes Who owns the building? Is an agreement needed to access data for demo purposes?	NO NO private owner No Ves, owner consent is required X Yes, consent from building occupants is required □





3.2 TERNI

The main coordinator of the Terni's Pilot Site is ASM TERNI S.p.A. ASM is an Italian multi utility company, established in 1960 and fully owned by Terni municipality, specializing in water, gas, electricity and environmental services. It owns and operates the local power distribution network, covering a surface of 211 km² and delivering about 400 GWh to 65100 customers annually. Nowadays the ASM electric grid is characterized by a large number of distributed renewable energy sources embedded in the medium and low voltage distribution networks.

For the integration of EVs in Terni, the Pilot has the support of Emotion. Emotion is an Italian company specialized in the sector of electric mobility. Emotion strategy is focused on research, development and technical growth, with a focus on acquisitions aimed at increasing efficiency and global footprint within strategic energy and automation businesses.

Basically, ASM TERNI will run the WiseGRID trial at its own headquarters, located in a suburb of the city of Terni and using its MV network.

3.2.1 WG Cockpit Pilot Site details checklists

3.2.1.2 Integration with DSOs systems

3.2.1.1 Set-up

Information required

Database of distribution grid assets, including GIS information (geojson, postgis...)

Single-wire diagrams of distribution grid (including topology, line characterization, impedances, electrotechnical assets,...)– MV and LV (PSSE raw, ...) available in csv format and PSAF/CYME

Power Quality Analyzer (PQA)	
Manufacturer	TEAMWARE
Model	WALLY A RTU
Will it be available for monitoring?	Yes X No 🗆
Type of monitored signals (node voltages, line currents, switches and protective device states,)	Node Voltages, feeder currents, THD, frequency, short cir- cuits, overvoltages (minimum frequency detected 10 mHz). Supervision and remote control of the HV-MV and MV-LV cabins. Transfer of information requested by the TSO and Italian Authority for energy sector (ARERA).
Frequency of data acquisition	25.6 ksample/sec
Approx. amount of monitored signals in demo site	To be evaluated
Will it be available for controlling field assets (self-healing features)?	Yes No X
Which protocol is available for integration with third parties?	Ethernet 100 Mb (Internet protocol)USB Device

Х

Х





 INIODEM GSINI/GPRS/UNITS 	•	Modem	GSM/GPRS/UMTS
--	---	-------	---------------

• GPS

AMI/AMR		
Manufacturer		Ericsson
Model		
Approx. number of smart meters in demo site		3 SM 5 PQA
Communication with Smart Meters (GPRS, PLC, etc.)		SM: Modem GPRS PQA: LAN
Frequency of readouts from smart meters		SM: 15 minutes PQA: 1 hour and trigger event
Frequency of readouts from concentrators		Every day
Which protocol is available for integration with thir ties?	d par-	SM: RS232 PQA: • Ethernet 100 Mb (Internet protocol) • USB Device • Modem GSM/GPRS/UMTS • GPS

3.2.1.3 RES and Electric Vehicles

RES	
Which RES units are present in your distribution grid? Please provide de- tails (number of units, types, aver- age peak power, ratio compared to overall demand)	1,200 PV plants, 6 Hydro power plants, 1 waste to energy and 4 bio- mass power plants and are connected to the network. About 50 % of energy demand is supplied by RES (2016):
	 29 GWh from Solar Energy (26 GWh supplied to the net- work, because 3 GWh is the amount of the energy self- consumed by the prosumers).
	- 70 GWh from Hydropower.
	- 79 GWh from Biomass and waste to energy.
	- Overall consumption was 380 GWh.
	 25 GWh supplied to the national transmission network as reverse power flow.
	Peak Power:





	- Consumption: 72 MW	
	- Production from RES: 39 MW	
	- Absorption from National Transmission Grid: 58 MW	
	 Injection to National Transmission Grid (reverse power flow): 22 MW 	
	Average Power:	
	- Consumption: 42 MW	
	- Production from RES: 22 MW	
	- Absorption from National Transmission Grid: 26 MW	
	 Injection to National Transmission Grid (reverse power flow): 3 MW 	
Are you currently monitoring pro- duction of those units? How? (SCADA, AMI,Protocols)	The units are monitored by AMI.	
Are you in position of controlling RES units? (production curtailment, power factor) How? (direct con- trol, signalling to third party)	Not at all. Every inverter of the PV power plants is equipped with a control system which requests power reduction when volt-age/frequency decreases/increases. These prescriptions are carried out by the manufacturer but the DSO cannot control how the regulation is working, a proper equipment should be deployed to control RES unit. Some producers/prosumers will be invited to participate in DR campaigns leveraging on self-consumption increasing (i.e. Nobel grid test scenarios).	

Electric Vehicles	
Are there electric vehicle charging stations deployed in your distribution grid? Please provide details (number of units, demand profile, ratio compared to overall demand)	6
Are you currently monitoring demand of those units? How? (SCADA, AMI, Proto- cols)	The units are moni- tored by AMI.
Are you in position of controlling the operation of the charging points? (start/stop operations, limit supply) How? (direct control, signalling to third party)	No

3.2.2 WiseCOOP, WiseCORP, WiseHOME, WG RESCO and WG STaaS VPP Pilot Site details checklists

3.2.2.1 Aggregator information

Information required	
Approx. amount of custom- ers/members of coopera- tive/DSO	65,000 Customer (DSO)




Please provide database with details on custom- ers/members (location, pro- file) – <u>No personal infor-</u> <u>mation required</u>	64,700 (LV) – 300 (MV); they are located in Terni and the surrounding area		
Existing customer types	Commercial/tertiary (LV): X Commercial/tertiary (MV): X Residential (LV): X Others: 1,300 production plants		
Number of custom- ers/members equipped with smart meters	65,000		
Frequency of readings from smart meters	1 time a month (LV) – each 15 minutes (MV)		
When do the smart meter readings become available to you?	2/3 days		

3.2.2.2 Building information

Information required				
Name of building	ASM's Headquarter			
Location (coordinates)	42.567361, 12.607000			
Structural information (e.g. surface, di- mensions, floors, areas, etc.)	ASM Terni buildings comprising i) a 4,050 m ² three-storey of- fice building; ii) a 2,790 m ² single-storey building consisting of technical offices, a computer centre and an operation control centre and iii) a 1,350 m ² warehouse.			
Usage (e.g. purpose, occupants, working times)	Administration, technical offices, operational, front office. 400 occupants. Occupancy Schedule: The operation control centre located at the single-storey build- ing is open 24 hours a day, 7 days a week. Monday – Friday: office building and warehouse open 07:00- 08:00 occupants arrive from 07:30-08:30, depart from 17:10- 18:10. From June to September occupants arrive from 07:00- 08:00 and depart from 14.00 to 15.00 pm. Saturday: open from 07:00 am to 13:00 pm. Sunday: Closed			
Available equipment				





Sensors (please focus especially on oc- cupancy and environmental sensors, e.g. temperature, humidity, luminance, IAQ, etc.)	Νο			
Controllable assets (please focus especially on energy hungry assets, e.g. HVAC, lighting, pool equipment, etc.)	Yes ; please, provide details: HVACs			
Local electricity generation (em- phasis on RES)	Yes; please, provide details: two PV arrays (180 kWp and 60 kWp)			
	Yes; please, provide details: 66 kWh battery energy storage;			
Storage (incl. Electric Vehicles)	Six EVs: a Renault Zoe R240 featuring a 11-kWh lithium-ion bat- tery is already in use in ASM TERNI headquarters, fed by a SPOTLINK - EVO filling station. The other units will be put in operation over the WISEGRID project by the EMOTION partner.			
	Yes			
	Teamw <mark>are -</mark> WALLY RTU A (5 seconds)			
Smart meters/	Landis+ <mark>Gyr</mark> – ZMD (5 seconds)			
Power analysers	Both meters are connected to SMX, which interrogates the me- ter every 5 seconds and sends data to ASM servers devoted to European projects.			
Building Management System	No			
Others	No			
Approx. building annual electricity con- sumption	800 MWh			
Approx. annual electricity production (if RES)	200 MWh (PV)			
Metering				
Are you metering particular are- as/assets demand independent- ly? (sub-metering)	No			
Frequency of readouts	15 minutes – 1 month			
Historical readouts available (his- torical traces of consumption is needed to calibrate/train models)	Yes; please, provide details: 5 years			
Price history available	No			
Billing				
	Energy Pricing & cost structure:			
	F1 0.17356 € (Monday - Friday from 08:00-19:00)			
Current tariff plan	F2 0.17148 € (Monday – Friday from 07:00-8:00. and from 19:00-23:00; Saturday from 07:00 a.m. to 23:00 p.m.)			
	F3 0.14599 € (Monday – Friday from 23:00-07:00; Sunday and			





		Public Holiday)
	Current involvement in demand response programmes	Νο
Legal		
	Who owns the building?	Municipality of Terni
	Is an agreement needed to access data for demo purposes?	Yes, owner consent is required
	Is an agreement needed to take actions over assets for demo purposes?	Yes, owner consent is required

3.2.2.3 Available controllable assets

Information required								
Manufacturer/Model			RHC	OSS THAE	TY2160			
Available protocol for monitoring/control (please elaborate on how the asset setpoints or measurements can be accessed)		No						
Is it possible to capt apply (e.g. temperature of	ure the setpoints that on thermostats or dimming	t users glevels)?	I do not know					
Controllability restric tractual, comfort)	ctions (technical, lega	al, con-	Νο					
Energy demand of asset – frequency of readouts			There is not a meter dedicated to the controllable as- sets now; in the next months some SMXs will be con- nected to some SHICs (Smart Controllers) to manage HVACs.					
Wh <mark>e</mark> n are the readouts available to you or to third parties?								
Are these readings personal/sensitive data ac- cording to European or national legislation?		No						
Energy demand of asset – historical readouts available		No						
Please, provide any te	echnical documentatio	on availa	ble					
	HVAC System – RHC	SS Heat	Pum	p Systen	n			
	Туре	Descrip	tion		Value		Unit	
Specifications	Heating & Cooling	RHOSS THAET	/2160)				
	Installed capacity	Electric	al Lo	ad	56.2		kWe	
		Heating	3		175.0		kWth	
		Cooling	S		159.8		kWth	





We will also be able to use:

Number of units	Producer	Model	Power (W)
1	ITELCO	K49R40	1100
4	DAIKIN	RXS25L2V1B	900

3.2.2.4 Tariff information

Information required		
Provide a list the retailers that offer tariffs that can be applied to your build- ings	All the Italian retailers (Um- bria Energy, Enel,)	
What types of time-of-use tariffs are there (single period, 2 periods, 3 periods, etc.)	3 Periods	
For time-of-use tariffs, what is the minimum reading frequency for con- sumption (1 hour, 15 minutes, etc.)	1 hour	
Is there a differentiation of tariffs based on active power? Please provide information.	No	
Is there a differentiation of tariffs based on voltage? Please provide infor- mation.	Yes (MV/LV)	
Are there any other types of differentiation and/or restrictions that limit the selection of a tariff plan? Please provide information.	No	
Are dynamic price tariffs available in your region or by your supplier? Is your building eligible for them? Please provide information.	No	
Any other comments/remarks regarding tariff ruling in your country?	No	

3.2.3 WiseEVP Pilot Site details checklist

3.2.3.1 Infrastructure

Charging points	
Manufacturer	Emotion
Model	EVO
How many charging points will be available at demo site?	4
Please provide database with charging points details, including GIS information (geojson, postgis)	Yes
Are charging points remotely accessible to third parties?	No
If yes, please specify protocol	





Are charge points currently managed by any control system of your own?	Yes
If yes, please specify third party integration possibilities (API, protocol)	API RESTFUL

Extra infrastructure

Are the charge points part of a larger facility?	No
If yes, will the facility participate in WiseGRID demonstrators (WiseCORP)?	Yes 🗆
	No 🗆
Are other elements (batteries, solar panels) installed or planned to be installed alongside the charge points?	No
If yes	Yes 🗌
Could they be monitored as part of the demonstrator:	No 🗆
Could they be controlled as part of the domonstrator?	Yes 🗆
could they be controlled as part of the demonstrator?	No 🗆

3.2.3.2 Electric vehicles

Electric vehicles Manufacturer Renault Model Zoe How many vehicles will be available at 6 demo site? Database with electric vehicle details YES Are vehicles currently monitored? If YES yes, please specify Details of hardware at vehicle CUSTOM OBD DEVICE Details of monitoring system Further explained in documentation already sent to ETRA Data retrieved from vehicles Further explained in documentation already sent to ETRA Frequency of data readout 20 seconds

3.2.3.3 Scheduling systems





Scheduling systems	
Are you currently using any system for EV vehicle availability scheduling? (e.g. times when vehicle is required by the organization, expected distances to travel, vehicle booking)	YES
If yes, could you provide details on the information handled by this system (availability scheduling, min. charge constraints, etc.)	Further explained in documentation already sent to ETRA

3.3 FLANDERS

The main coordinator of the Flanders' Pilot Site is Ecopower cvba. Ecopower was founded in 1992 as a cooperative under Belgian law. The organisation has three main goals: investing in renewable energy; supplying 100% green electricity to our cooperative members and promoting a rational use of energy (and renewable energy and the cooperative business model in general).

For the integration of EVs, partnership was formed with Partago cvba. Partago was founded in 2015 as a cooperative under Belgian law. The organisation is active solely in Ghent and has two main goals: 1) to provide access to 100% electric cars to the cooperative members and 2) to promote a transition towards a healthy and sustainable city.

The WiseGRID Pilot Site in Flanders, Belgium consists of 1 main pilot area in the City of Ghent and some smaller complementary test sites. The smaller project sites have been investigated as they are potentially capable of combining PV, batteries, charging stations and EVs on a small but manageable scale.

3.3.1 WiseCOOP, WiseCORP, WiseHOME, WG RESCO and WG STaaS/VPP Pilot Site details checklists

3.3.1.1 Oxfam

3.3.1.1.1 Aggregator information

Information required	
Approx. amount of customers/members of cooperative/DSO	50,000 but real number depends of participants in aggregation role.
Please provide database with details on custom- ers/members (location, profile) – <u>No personal information</u> <u>required</u>	
	Commercial/tertiary (LV)
Existing customer types	Commercial/tertiary (MV) X
	Residential (LV) X





	Others \Box , please elaborate
Number of customers/members equipped with smart me- ters	Depends on NobelGRID SMX final imple- mentation.
Frequency of readings from smart meters	Up to 1 minute data real time.
When do the smart meter readings become available to you?	Depends on the speed of the data coming from the SMX through the WG IOP.

3.3.1.1.2 Building information

Information required	
Name of building	OXFAM
Location (coordinates)	Ververijstraat 17, 9040 Sint-Amandsberg (51.052981, 3.744632)
Structural information (e.g. surface, dimensions, floors, areas, etc.)	1 building layer
Usage (e.g. purpose, occupants, working times)	Administration office. Working times: 07:00 – 18:30 (Mon-Fri).
Available equipment	
Sensors (please focus especially on occupancy and environmental sensors, e.g. temperature, humidity, luminance, IAQ, etc.)	No X Yes \Box ; please, provide details:
Controllable assets (please focus especially on energy hungry assets, e.g. HVAC, lighting, pool equipment, etc.)	No X Yes \Box ; please, provide details:
Local electricity generation (emphasis on RES)	No 🗆 Yes X ; please, provide details: PV installation 82.62 kWp.
Storage (incl. Electric Vehicles)	No X Yes \Box ; please, provide details: Negotiation with Ampère Energy on going
Smart meters/ Power analysers	No \Box Yes X; please, provide details (with emphasis on frequency of metering and when the data can become ac- cessible to you or a third party): Currently: AMR (15 minutes day after) Foreseen: investment of 1,600 \in to have impulses locally available which means real time data to be read by the SMX.
Building Management System	No X Yes : please, provide details (e.g. about make, capabilities and connected assets):
Others	





Approx. building annual electricity consumption		28,000 kWh grid offtake/year (app. 35,000 kWh fi- nal electricity consumption)
Approx. annual electricity production (if RES)		75,000 kWh/year
Meteri	ing	
	Are you metering particular areas/assets demand independently? (sub-metering)	No Yes ; please, provide details (e.g. how, which assets, their importance to building consumption, etc.):
	Frequency of readouts	IBD
	Historical readouts available (historical traces of consumption is needed to calibrate/train models)	No Yes ; please, provide details: Main meter: yes (3 years, freq. 15 min) PV production: yes (3 years, freq. 15 min)
	Price history available	No 🗆 Yes X; please, provide details: Ecopower is supplier for grid off take and purchases grid injection of this PV installation.
Billing		
	Current tariff plan	0.259 €/ kWh incl. VAT (ECOPOWER tariff)
	Current involvement in demand response programmes	NO
Legal		
	Who owns the building?	OXFAM
Is an agreement needed to access data for demo purposes?		No \Box Yes, owner consent is required ${\bf X}$ Yes, consent from owner and building occupants is required \Box
	Is an agreement needed to take actions over assets for demo purposes?	No Yes, owner consent is required X Yes, consent from owner and building occupants is required

3.3.1.2 City office Eeklo

3.3.1.2.1 Aggregator information





Information required	
Approx. amount of customers/members of cooperative/DSO	50,000 but real number depends of participants in aggregation role.
Please provide database with details on custom- ers/members (location, profile) – <u>No personal information</u> <u>required</u>	
	Commercial/tertiary (LV) 🗌
Existing customer types	Commercial/tertiary (MV) ${\sf X}$
	Residential (LV) X
	Others \Box , please elaborate
Number of customers/members equipped with smart me-	Depends on NobelGRID SMX implementa- tion.
Frequency of readings from smart meters	Up to 1 minute data real time.
When do the smart meter readings become available to you?	Depends on the speed of the data coming from the SMX through the WG IOP.

3.3.1.2.2 Building information

mormation required		
Name of building	City office Eeklo (urban administrative and technical center)	
Location (coordinates)	Industrielaan 2, 9900 Eeklo (51.182497, 3.546645)	
Structural information (e.g. surface, dimensions,	Front building: 3 building layers, 2100 m ²	
floors, areas, etc.)	Back building: 2 building layers, 1400 m ²	
	Front building: administrative center	
Usage (e.g. purpose, occupants, working times)	Back building: technical service incl. stockroom, work- place and parks department.	
	Working times: 07:00-18:30 (Mon-Fri)	
	Personnel: 130	
Available equipment		
Sensors (please focus especially on occupancy and environmental sensors, e.g. temperature, humidity, luminance, IAQ, etc.)	No X Yes]; please, provide details:	
Controllable assets (please focus especially on energy hungry assets, e.g. HVAC, lighting, pool equipment, etc.)	No X Yes □; please, provide details:	
Local electricity generation (emphasis on RES)	No 🗌 Yes X; please, provide details:	





	 2 PV installations (2x 5 kWp on front building and back building)
Storage (incl. Electric Vehicles)	No X Yes \Box ; please, provide details:
Smart meters/ Power analysers	No Yes X - 3 Flukso and 3 SMX from NobelGRID: 1 SMX and Flukso for offtake and injection building, 2 SMX and Flukso for production 2 PV installations
Building Management System	No \Box Yes X; please, provide details (e.g. about make, capabilities and connected assets): Centralized control unit for heating building, with heat recuperation on ventilation system.
Others	
Approx. building annual electricity consumption	180,000 kWh
Ap <mark>p</mark> rox. annual electricity production (if RES)	PV Eeklo city office: 9,000 kWh
Metering	
Are you metering particular areas/assets demand independently? (sub-metering)	No 🗆 Yes X; PV : 2x SMA sunny boy
Frequency of readouts	5-15 min data
Historical readouts available (historical traces of consumption is needed to calibrate/train models)	No X Yes 🗆; please, provide details:
Price history available	No □ Yes X ; please, provide details: Ca. 115 €/MWh
Billing	
Current tariff plan	Ca. 115 €/MWh
Current involvement in demand re- sponse programmes	No
Legal	
Who owns the building?	Stad Eeklo
Is an agreement needed to access data for demo purposes?	No \Box Yes, owner consent is required X Ves. consent from owner and building occupants is re-





	quired 🗆
	No 🗆
Is an agreement needed to take actions over assets for demo purposes?	Yes, owner consent is required ${f X}$ Yes, consent from owner and building occupants is re-
	quired 🗆

3.3.1.3 Ecopower office

3.3.1.3.1 Aggregator information

Information required	
Approx. amount of customers/members of cooperative/DSO	50,000 (but real number depends on partic- ipants in Aggregation role
Please provide database with details on custom- ers/members (location, profile) – No personal information required	
	Commercial/tertiary (LV) 🗆
Existing customer types	Commercial/tertiary (MV) X
	Residential (LV) X
	Others \Box , please elaborate
Number of customers/members equipped with smart me- ters	Depends on Nobelgrid SMX implementa- tion.
Frequency of readings from smart meters	Up to 1 minute data real time
When do the smart meter readings become available to you?	Depends on the speed of the data coming from the SMX through the WG IOP.

3.3.1.3.2 Building information

Information required	
Name of building	Ecopower office
Location (coordinates)	51.199360, 4.431400
Structural information (e.g. surface, dimensions, floors, areas, etc.)	Only third floor of n° 3 (middle part), 750 m^2 surface area
Usage (e.g. purpose, occupants, working times)	Office. Working times: 08:30-18:30 (Mo-Fri).
Available equipment	





Sensors (please focus especially on occupancy and environmental sensors, e.g. temperature, humidity, luminance, IAQ, etc.)	No Yes X; please, provide details: d daylight/occupancy sensors on DALI controllable through NobelGrid SHIC	
Controllable assets (please focus especially on energy hungry assets, e.g. HVAC, lighting, pool equipment, etc.)	No \Box Yes $X;$ please, provide details: Lights and PV inverter	
Local electricity generation (emphasis on RES)	No \Box Yes X ; please, provide details: 2065 Wpeak, monophase with Nobelgrid experimental controllable inverter (by Nobel Grid partner Uninova)	
Storage (incl. Electric Vehicles)	No 🗆 Yes X; please, provide details: 96 V Nobelgrid Battery pack. Battery capacity 672 Wh	
Smart meters/ Power analysers	No Yes X; please, provide details (with emphasis on frequency of metering and when the data can become accessible to you or a third party): A+, A- and PV production (when operational) nearly real time 1 min through NobelGrid SMX.	
Building Management System	No \Box Yes X ; please, provide details (e.g. about make, capabilities and connected assets): Only WAGO PLC with DALI gateway to control lighting.	
Others		
Approx. building annual electricity consumption	17,000 kWh	
Approx. annual electricity production (if RES)	1,700 kWh	
Metering		
Are you metering particular areas/assets demand independently? (sub-metering)	No Yes X; please, provide details (e.g. how, which as- sets, their importance to building consumption, etc.): Sub-metering of PV production	
Frequency of readouts	Pulse based 10 Wh/pulse	
Historical readouts available (historical traces of consumption is needed to calibrate/train models)	No 🗖 Yes X; please, provide details: Since 25/05/2017	
Price history available	No \Box Yes X ; please, provide details: ECOPOWER tariff	
Billing		
Current tariff plan	Ecopower	





	Current involvement in demand re- sponse programmes	Nobelgrid
Legal		
	Who owns the building?	It is rented from real estate party.
	Is an agreement needed to access data for demo purposes?	No X Yes, owner consent is required Yes, consent from owner and building occupants is re- quired
	Is an agreement needed to take actions over assets for demo purposes?	No X (only ECOPOWER property will be taken over: lighting and Nobelgrid PV/Battery) Yes, owner consent is required Yes, consent from owner and building occupants is re- quired

3.3.1.3.3 Available sensing equipment

Information required	
Manufacturer/Model	
Sensor type (e.g. temperature, oc- cupancy, IAQ, luminance, etc.)	Luminance/occupancy
Available protocol for monitor- ing/control (please elaborate on how the sensor readings can be accessed)	DALI
Sensor readings – frequency of readouts	
Are these readings person- al/sensitive data according to Euro- pean or national legislation?	No X Yes 🗆 I do not know 🗆
Sensor readings – historical readouts available	NO
Please, provide any technical documentation available	

3.3.1.3.4 Available controllable assets

Information required		
Manufacturer/Model	Uninova	controllable





	inverter
Available protocol for monitoring/control (please elaborate on how the asset setpoints or measurements can be accessed)	
Is it possible to capture the setpoints that users apply (e.g. temperature on thermo- stats or dimming levels)?	No 🗆 Yes 🗆 I do not know X
Controllability restrictions (technical, legal, contractual, comfort)	TBD
Energy demand of asset – frequency of readouts	
When are the readouts available to you or to third parties?	
Are these readings personal/sensitive data according to European or national legislation?	No X Yes 🗆 I do not know 🗔
Energy demand of asset – historical readouts available	

Information required	
Manufacturer/Model	Lighting
Available protocol for monitoring/control (please elaborate on how the asset setpoints or measurements can be accessed)	DALI
Is it possible to capture the setpoints that users apply (e.g. tempera- ture on thermostats or dimming levels)?	No 🗆 Yes X I do not know 🗔
Controllability restrictions (technical, legal, contractual, comfort)	Comfort levels lighting
Energy demand of asset – frequency of readouts	Real time through MQTT/SMX
When are the readouts available to you or to third parties?	Nearly real time through SMX
Are these readings personal/sensitive data according to European or national legislation?	No X Yes I do not know
Energy demand of asset – historical readouts available	No submetering for lighting. Only total consumption of office.





3.3.1.3.5 Tariff information

Information required	
Provide a list the retailers that offer tariffs that can be ap- plied to your buildings	
What types of time-of-use tariffs are there (single peri- od, 2 periods, 3 periods, etc.)	Standard: single. Only dynamic as alternative.
For time-of-use tariffs, what is the minimum reading fre- quency for consumption (1 hour, 15 minutes, etc.)	15 minutes
Is there a differentiation of tariffs based on active power? Please provide information.	Not for the site connections (LV).
Is there a differentiation of tariffs based on voltage? Please provide information.	
Are there any other types of differentiation and/or re- strictions that limit the selec- tion of a tariff plan? Please provide information.	
Are dynamic price tariffs available in your region or by your supplier? Is your building eligible for them? Please pro- vide information.	Dynamic tariffs are not yet operational in Belgium. Ecopower will simu- late one.
Any other comments/remarks regarding tariff ruling in your country?	Capacity tariff is being discussed, but not implemented.

3.3.1.4 Thrift shop Eeklo

3.3.1.4.1 Aggregator information

Information required	
Approx. amount of customers/members of cooperative/DSO	50,000 but real number depends of participants in aggregation role.
Please provide database with details on custom- ers/members (location, profile) – <u>No personal information</u> <u>required</u>	
Existing customer types	Commercial/tertiary (LV) 🗌





	Commercial/tertiary (MV) ${\sf X}$
	Residential (LV) X
	Others 🗌, please elaborate
Number of customers/members equipped with smart me- ters	Depends on NobelGRID SMX implementa- tion.
Frequency of readings from smart meters	Up to 1 minute data real time.
When do the smart meter readings become available to you?	Depends on the speed of the data coming from the SMX through the WG IOP.

3.3.1.4.2 Building information

mormation required	
Name of building	Thrift store Eeklo (Kringwinkel Eeklo)
Location (coordinates)	Slachthuisstraat 2B, 9900 Eeklo (51.18, 3.55)
	Building (3,151 m ²) contains 3 zones:
Structural information (e.g. surface, dimensions, floors, areas, etc.)	Zone 1: working place for repairs and sorting of sec- ond hand goods (1 floor).Zone 2: shopping space for customers (1 floor)Zone 3: 2 floors. Ground floor: counter. First floor: office spaces, dining room.
	Purpose: see previous box.
Lisage (e.g. nurnose occupants working times)	30 occupants.
Usage (e.g. purpose, occupants, working times)	Open Tuesday- Saturday 09:00-18:00
	Closed Sunday & Monday
Available equipment	
Sensors (please focus especially on occupancy and environmental sensors, e.g. temperature, humidity, luminance, IAQ, etc.)	No X Yes □; please, provide details:
Controllable assets (please focus especially on energy hungry assets, e.g. HVAC, lighting, pool equipment, etc.)	No X Yes \Box ; please, provide details:
	No 🗆 Yes X; please, provide details:
Local electricity generation (emphasis on RES)	1 PV on thrift store building (34.6 kWp)
Storage (incl. Electric Vehicles)	No X Yes □; please, provide details:
Smart meters/	No 🗍 Yes X: please, provide details (with emphasis on
Power analysers	frequency of metering and when the data can become accessible





		to you or a third party):
		2 Flukso + 2 SMX from NobelGRID: 1 SMX and Flukso for PV production, 1 SMX and Flukso for offtake and injection.
	Building Management System	No X Yes \Box ; please, provide details (e.g. about make, capabilities and connected assets):
	Others	
Approx	. building annual electricity consumption	60,000 kWh
Approx	annual electricity production (if RES)	33,300 kWh
Meteri	ng	
	Are you metering particular areas/assets demand independently? (sub-metering)	No \Box Yes X; please, provide details (e.g. how, which assets, their importance to building consumption, etc.): PV: 6 x SMA sunny boy
	Frequency of readouts	5-15 min data
	Historical readouts available (historical traces of consumption is needed to calibrate/train models)	No 🗆 Yes X; please, provide details: Production, offtake, injection
	Price history available	 No □ Yes X; please, provide details: PV: property of Ecopower. Rent for PV-installation to Ecopower: 457.52 EUR/year. Tariff autoconsumption: 0.066 EUR. Tariff offtake grid: standard Ecopower tariff. Tariff injection PV: TBD, e.g. % endex.
Billing		
	Current tariff plan	Ecopower standard
	Current involvement in demand response programmes	H2020 Nobelgrid
Legal		
	Who owns the building?	Kringwinkel Meetjesland vzw (Komosie)
	Is an agreement needed to access data for demo purposes?	No Yes, owner consent is required X Yes, consent from owner and building occupants is required





Νο[
Is an agreement needed to take actions Yes, over assets for demo purposes? Yes, requ	, owner consent is required ${f X}$, consent from owner and building occupants is uired \Box

3.3.1.4.3 Tariff information

Information required	
Provide a list the retailers that offer tariffs that can be ap- plied to your buildings	
What types of time-of-use tariffs are there (single peri- od, 2 periods, 3 periods, etc.)	Standard: single. Only dynamic as alternative.
For time-of-use tariffs, what is the minimum reading fre- quency for consumption (1 hour, 15 minutes, etc.)	15 minutes
Is there a differentiation of tariffs based on active power? Please provide information.	Not for the site connections (LV).
Is there a differentiation of tariffs based on voltage? Please provide information.	
Are there any other types of differentiation and/or re- strictions that limit the selec- tion of a tariff plan? Please provide information.	

3.3.1.5 Rotselaar Mill

3.3.1.5.1 Aggregator information

mornation required	
Approx. amount of customers/members of cooperative/DSO	50,000 but real number depends of participants in aggregation role.
Please provide database with details on custom- ers/members (location, profile) – <u>No personal information</u> <u>required</u>	
Existing customer types	Commercial/tertiary (LV)





	Commercial/tertiary (MV) ${\sf X}$
	Residential (LV) X
	Others \Box , please elaborate
Number of customers/members equipped with smart me-	Depends on NobelGRID SMX implementa-
ters	tion.
Frequency of readings from smart meters	Up to 1 minute data real time.
When do the smart meter readings become available to you?	Depends on the speed of the data coming from the SMX through the WG IOP.

3.3.1.5.2 Building information

Information required	
Name of building	Rotselaar Mill Site
Location (coordinates)	50.947 <mark>239,</mark> 4.702859
Structural information (e.g. surface, dimensions, floors, areas, etc.)	8 private dwellings, 1 old bakery house and 1 water mill muse- um.
Usage (e.g. purpose, occupants, working times)	
Available equipment	
Sensors (please focus especially on oc- cupancy and environmental sensors, e.g. temperature, humidity, luminance, IAQ, etc.)	No X Yes □; please, provide details:
Controllable assets (please focus especially on energy hungry assets, e.g. HVAC, lighting, pool equipment, etc.)	No X Yes \Box ; please, provide details:
Local electricity generation (em- phasis on RES)	No Yes X; please, provide details: Watermill = hydropower: 65 kW permanently
Storage (incl. Electric Vehicles)	No 🗆 Yes X; please, provide details: 1 public EVSE
Smart meters/ Power analysers	No \Box Yes X; please, provide details (with emphasis on frequency of metering and when the data can become accessible to you or a third par- ty): Total number of meters: 8 private (of which 6 SMX), 1 for bak- ery (with SMX), 2 mill building (with SMX). 1 AMR (4-Quadrant meter) for turbine production with official 15 min production data (available day-after).





	Building Management System	No X Yes \Box ; please, provide details (e.g. about make, capabilities and connected assets):
	Others	
Approx sumpti	 k. building annual electricity con- ion 	18,000 kWh
Approx RES)	x. annual electricity production (if	450 MWh
Meter	ing	
	Are you metering particular are- as/assets demand independent- ly? (sub-metering)	No \Box Yes X; please, provide details (e.g. how, which assets, their importance to building consumption, etc.): Smart meters = submeters of site: total number of meters: 8 private (of which 6 SMX), 1 for bakery (with SMX), 2 mill building (with SMX). 1 AMR (4-Quadrant meter) for turbine production with official 15 min production data (available day-after).
	Frequency of readouts	instantaneous read-out through MQTT
	Historical readouts available (his- torical traces of consumption is needed to calibrate/train models)	No 🗌 Yes X; please, provide details:
	Price history available	No Yes X; please, provide details: only for Ecopower clients: 6 households + bakery + mill building
Billing		
	Current tariff plan	Ecopower standard
	Current involvement in demand response programmes	H2020 Nobelgrid
Legal		
	Who owns the building?	Ecopower + 9 households
	Is an agreement needed to access data for demo purposes?	No \Box Yes, owner consent is required X Yes, consent from owner and building occupants is required \Box
	Is an agreement needed to take actions over assets for demo purposes?	No \Box Yes, owner consent is required X Yes, consent from owner and building occupants is required \Box

3.3.1.5.3 Tariff information





Information required	
Provide a list the retailers that offer tariffs that can be ap- plied to your buildings	
What types of time-of-use tariffs are there (single peri- od, 2 periods, 3 periods, etc.)	Standard: single. Only dynamic as alternative.
For time-of-use tariffs, what is the minimum reading fre- quency for consumption (1 hour, 15 minutes, etc.)	15 minutes
Is there a differentiation of tariffs based on active power? Please provide information.	Not for the site connections (LV).
Is there a differentiation of tariffs based on voltage? Please provide information.	
Are there any other types of differentiation and/or re- strictions that limit the selec- tion of a tariff plan? Please provide information.	
Are dynamic price tariffs available in your region or by your supplier? Is your building eligible for them? Please pro- vide information.	Dynamic tariffs are not yet operational in Belgium. Ecopower will simu- late one.
Any other comments/remarks regarding tariff ruling in your country?	Capacity tariff is being discussed, but not implemented.

3.3.1.6 Bio-ecological and energy-efficient home

3.3.1.6.1 Aggregator information

Information required	
Approx. amount of customers/members of cooperative/DSO	50,000 but real number depends of participants in aggregation role.
Please provide database with details on custom- ers/members (location, profile) – <u>No personal information</u> <u>required</u>	
Existing customer types	Commercial/tertiary (LV)





	Commercial/tertiary (MV) ${\sf X}$
	Residential (LV) X
	Others \Box , please elaborate
Number of customers/members equipped with smart me- ters	Depends on NobelGRID SMX implementa- tion.
Frequency of readings from smart meters	Up to 1 minute data real time.
When do the smart meter readings become available to you?	Depends on the speed of the data coming from the SMX through the WG IOP.

3.3.1.6.2 Building information

Information required	
Name of building	Jacobs Nest
Location (coordinates)	Rodonkstraat 22, 9030 Ghent; 51.07705 3.66859
Structural information (e.g. surface, dimensions, floors, areas, etc.)	Surface area (A): 220 m ² Compactness: 2.30 3 floors Semi-detached house
Usage (e.g. purpose, occupants, working times)	Housing
Available equipment	
Sensors (please focus especially on occupancy and environmental sensors, e.g. temperature, hu- midity, luminance, IAQ, etc.)	 No ☐ Yes X; please, provide details: outside temperature inside humidity temperature of solar boiler electricity consumption monitoring (Flukso) electricity injection from PV monitoring EVSE consumption monitoring
Controllable assets (please focus especially on energy hungry assets, e.g. HVAC, lighting, pool equipment, etc.)	No \Box Yes X ; please, provide details: Heat pump on/off controllable (model: Stiebel Eltron LWZ403, 6.4kW, for heating, warm water and ventila- tion)
Local electricity generation (emphasis on RES)	No \Box Yes X; please, provide details:





	18 x 245 W solar panels, area 30 m ² , approximately 4100 kWh / year production.	
Storage (incl. Electric Vehicles)	No □ Yes X; please, provide details: - Renault Zoé with 40 kWh battery, in a sharing system of Partago.	
Smart meters/ Power analysers	No Yes X; please, provide details (with emphasis on frequency of metering and when the data can become accessible to you or a third party): Flukso, 3 electricity phase electricity metering (offtake + feed-in) + submetering EVSE consumption. Extra PV production submeter to be installed.	
Building Management System	No X Yes \Box ; please, provide details (e.g. about make, capabilities and connected assets):	
Others	Solar panels for hot water production: area 5.5 m ² .	
Approx. building annual electricity consumption	2,000 kWh / year net energy consumption from the grid.	
Approx. annual electricity production (if RES)	4,100 kWh	
Metering		
Are you metering particular areas/assets demand independently? (sub-metering)	No Yes X; please, provide details (e.g. how, which as- sets, their importance to building consumption, etc.): Yes, see Flukso above.	
Frequency of readouts		
Historical readouts available (historical traces of consumption is needed to calibrate/train mod- els)	No Yes X; please, provide details: Are being de- ployed now. Very rude measurements by monthly manual input of the meters.	
Price history available	No \Box Yes X ; please, provide details: only for Customer of Ecopower.	
Billing		
Current tariff plan	Fixed price: 0.26€ / kWh incl VAT	
Current involvement in demand response programmes	H2020 Nobel Grid	
Legal		





Who owns the building?	A Cooperative member of Ecopower.
Is an agreement needed to access data for demo purposes?	No Yes, owner consent is required X Yes, consent from owner and building occupants is re- quired
Is an agreement needed to take actions over assets for demo purposes?	No Yes, owner consent is required X Yes, consent from owner and building occupants is re- quired

3.3.1.6.3 Available controllable assets

Information required		
Manufacturer/Model	Stiebel Eltron LWZ 403 compact heatpump	
Available protocol for monitoring/control (please elaborate on how the asset setpoints or measurements can be accessed)	EVU port: on/ off switch of heatpump	
Is it possible to capture the setpoints that users apply (e.g. temperature on thermostats or dimming levels)?	No 🗆 Yes 🗆 I do not know 🗙	
Controllability restrictions (technical, legal, contractual, comfort)	The heat pump provides heating, so user com- fort needs to be guaranteed.	
Energy demand of asset – frequency of readouts	6.4 kW	
When are the readouts available to you or to third par- ties?	After manual checking on the interface of the heat pump. There is possibility of automatic read out via a serial port, but is currently not (planned to be) implemented.	
Are these readings personal/sensitive data according to European or national legislation?	No 🗌 Yes X I do not know 🗌	
Energy demand of asset – historical readouts available	Yes by very rough measurements, monthly manual read out.	
Please, provide any technical documentation available		
https://www.stiebel-eltron.com/en/home/products- solutions/renewables/heat_pump/air_water_heat_pumps/lwz_304_404_sol/lwz_404_sol/technical-		





data.html

3.3.1.6.4	Tariff information	
Information required		
Provide a list the retailers that offer tariffs that can be ap- plied to your buildings	Ecopower cvba	
What types of time-of-use tariffs are there (single peri- od, 2 periods, 3 periods, etc.)	Single tariff	
For time-of-use tariffs, what is the minimum reading fre- quency for consumption (1 hour, 15 minutes, etc.)		
Is there a differentiation of tariffs based on active power? Please provide information.	No	
Is there a differentiation of tariffs based on voltage? Please provide information.	No	
Are there any other types of differentiation and/or re- strictions that limit the selec- tion of a tariff plan? Please provide information.	Unknown	
Are dynamic price tariffs available in your region or by your supplier? Is your building eligible for them? Please pro- vide information.	Not yet. Planned for	2019
Any other comments/remarks regarding tariff ruling in your country?		

3.3.2 WiseEVP Pilot Site details checklist

	3.3.2.1	Infrastructure
--	---------	----------------

Charging points	
Manufacturer	Allego (public charging station)
	Schneider electric (Partago owned charging station), Blue Corner (Partago owned charging station)
Model	Allego; Schneider: Evlink2; Blue Corner: pro station.





How many charging points will be	6 charging points in the main Pilot Site, 2 of which are controlla- ble/real-time monitored; and for the rest of them, we can have charging log data (because of not owned by Partago).	
available at demo site?	Optional controllable charging points: the charging stations of Par- tago are spread over Gent, 4 of them are located at homes with solar installations.	
Please provide database with		
charging points details, including		
GIS Information (geojson, postgis)		
Are charge points remotely accessible to third parties?	Yes X No	
If yes, please specify proto- col		
Are charge points currently man- aged by any control system of your own?	Yes X No	
	- Schneider <mark>elect</mark> ric: OCPP	
If yes, please specify third party integration possibili- ties (API, protocol)	 None of the charging stations are monitored by a control system of our own, but by the control system of Mobility+ (mobilityplus.be) and the control system of Blue Corner (bluecorner.be). We can access data from their backend. API availability unknown. 	
Please provide any technical documentation available (charge points and monitoring system)		

Please, provide any technical documentation available (charge points and monitoring system) mobilityplus.be

evportal.be

Extra infrastructure	
Are the charge points part of a larger facility?	Yes □ No X
If yes, will the facility participate in WiseGRID demonstrators (WiseCORP)?	Yes 🗆 No 🗙
Are other elements (batteries, solar panels) installed or planned to be in- stalled alongside the charge points?	Yes X No 🗆
If yes Could they be monitored as part of the demonstrator?	Yes X





Could they be controlled as part of the demonstrator?	No 🗆	
	Yes]
	No X	

3.3.2.2 Electric vehicles

Electric vehicles			
Manufacturer	Renault Zoé and Nissan		
Model	Zoé 22kWh, Zoé 41kWh, Nissan eNV200 24 kWh		
How many vehicles will be available at demo site?	Total 26: 25 Zoé, 1 Nissan		
Database with electric vehicle de- tails			
Are vehicles currently monitored? If yes, please specify	Yes v	No 🗆	
Details of hardware at vehi- cle	INVERS Cloude	Boxx	
Details of monitoring sys- tem	Data is collected from car's can bus send via data connection to servers of INVERS, and set available via API's to our server. We get and set the data via the API of INVERS. Partago collects this data in his own database, which is accessible via API's.		
Data retrieved from vehi- cles	SOC, charging plug in/out, charging on/off, ignition on/off, mile- age, geolocalisation, doors status, handbrake status.		
Frequency of data readout	Upon request	by system (event).	

Please, provide any technical documentation available (electric vehicles and monitoring system)

1, CloudBoxx documentation is confidential by INVERS.

2, Renault Zoé: <u>https://nl.renault.be/voertuigen/elektrische-wagens/zoe/versies-en-prijzen.html#grade-</u> ZOE-2|specs

3, Nissan e-NV200 24kWh OPTIMA https://nl.nissan.be/voertuigen/nieuw/e-nv200/specificaties.html

3.3.2.3 Scheduling systems

Scheduling systems			
Are you currently using any system for EV vehicle availability schedul- ing? (e.g. times when vehicle is re- quired by the organization, ex-	Yes X	No 🗆	





pected distances to travel, vehicle booking)	
If yes, could you provide details on the information handled by this system (availability scheduling, min. charge constraints, etc.)	In house made platform. Users reserve cars via the frontend. Key is sent to their smartphone. They open the doors with their smartphone to use the car. They return the car after use to the charging station, if battery's stage of charge is lower than 70%. Backend registers all reservations and controls availability. Frontend on <u>https://app.partago.be</u> . Backend on <u>http://app.partago.be/admin</u> . API with status data of our fleet is publicly available and expanda- ble.

3.4 CREVILLENT

Crevillent is a municipality of the Valencian Region, Spain. It is located in the Range of Crevillent in the province of Alicante (Bajo Vinalopó region). The main coordinator in this Pilot Site is the electric Cooperative Crevillent, subsidiary of the Enercoop Group. Currently, the Electric Cooperative of Crevillent is a DSO and retailer that provides electricity to 14,315 consumers (13,047 households and 1,268 companies) in low voltage network and 30 consumers in medium voltage network (mainly industrial and service sector companies).

The entire energy production of the entity has zero emissions and hard work is done to get all the generated and distributed energy 100% clean.

3.4.1 WG Cockpit Pilot Site details checklists

3.4.1.1 Set-up

Information required

Database of distribution grid assets, including GIS information (geojson, postgis, ...)

Single-wire diagrams of distribution grid (including topology, line characterization, impedances, electrotechnical assets, ...)– MV and LV (PSSE raw, ...)

3.4.1.2 Integration with DSOs systems

SCADA	
Manufacturer	SITEL
Model	Is currently being upgraded
Will it be available for monitoring?	Yes X No 🗆
Type of monitored signals (node volt- ages, line currents, switches and pro- tective device states,)	node voltages, line currents, switches and protective device states
Frequency of data acquisition	ТВС
Approx. amount of monitored signals	

Х





in demo site		
Will it be available for controlling field assets (self-healing features)?	Yes X	No 🗆
Which protocol is available for inte- gration with third parties?	TB SPECIFIED	

AMI/AMR	
Manufacturer	ZIV / STGTEDIS
Model	Mostly - ZIV 5CTD-EIC - ZIV 5CTME2C47536 AVF
Approx. number of smart meters in demo site	12,000
Communication with Smart Meters (GPRS, PLC, etc.)	PLC
Frequency of readouts from smart meters	Hourly
Frequency of readouts from concen- trators	Hourly, collected from previous day.
Which protocol is available for inte- gration with third parties?	FTP/XML files

3.4.1.3 Field devices

Medium voltage grid

RES

Which elements are you currently monitoring with your SCADA (e.g. Fault Passage Indicators, protective relays, transformers)?	Fault Passage Indicators, protective relays, transformers		
Which elements are you able to con- trol from your SCADA (switches)?	Switches		

3.4.1.4 RES and Electric Vehicles





	the plants are located on rooftops.
Are you currently monitoring produc- tion of those units? How? (SCADA, AMI,Protocols)	Yes, SCADA.
Are you in position of controlling RES units? (production curtailment, power factor) How? (direct control, signal- ling to third party)	Yes, direct control.

Electric Vehicles	
Are there electric vehicle charging sta- tions deployed in your distribution grid? Please provide details (number of units, demand profile, ratio com- pared to overall demand)	Νο
Are you currently monitoring demand of those units? How? (SCADA, AMI, Protocols)	
Are you in position of controlling the operation of the charging points? (start/stop operations, limit supply) How? (direct control, signalling to third party)	

3.4.2 WiseCOOP, WiseCORP, WiseHOME Pilot Site details checklists

3.4.2.1 Aggregator information

Information required	
Approx. amount of customers/members of cooperative/DSO	15,000
Please provide database with details on customers/members (location, pro- file) – <u>No personal information required</u>	x
	Commercial/tertiary (LV)
	X
	Commercial/tertiary
Existing customer types	(MV) X
	Residential (LV) X
	Others \Box , please elabo-
	rate
Number of customers/members equipped with smart meters	12,000





Frequency of readings from smart meters	Hourly
When do the smart meter readings become available to you?	Daily

3.4.2.2 Mortuary

3.4.2.2.1 Building Information

Information required	
Name of building	Mortuary "Virgen de la Esperanza"
Location (coordinates)	691997.43 – 4235175.04
Structural information (e.g. surface, dimensions, floors, areas, etc.)	2 floors of 300 m ² each one
Usage (e.g. purpose, occupants, working times)	Mortuary – Public service
Available equipment	
Sensors (please focus especially on occupancy and environmental sensors, e.g. temperature, humidity, luminance, IAQ, etc.)	No X Yes □; please, provide details:
Controllable assets (please focus especially on energy hungry assets, e.g. HVAC, lighting, pool equipment, etc.)	No X Yes \Box ; please, provide details:
Local electricity generation (emphasis on RES)	No Yes X; PV plant of 6 kWp
Storage (incl. Electric Vehicles)	No X Yes \Box ; please, provide details:
Smart meters/ Power analysers	No Yes X; please, provide details (with emphasis on frequency of metering and when the data can become accessible to you or a third party): Models:
	- ZIV 5CTME2C47536 AVF
Building Management System	No X Yes : please, provide details (e.g. about make, capabilities and connected assets):
Others	
Approx. building annual electricity consumption	55,111 kWh
Approx. annual electricity production (if RES)	7,533 kWh
Metering	
Are you metering particular areas/assets demand independently? (sub-metering)	No X Yes \Box ; please, provide details (e.g. how, which assets, their importance to building consumption, etc.):





	Frequency of readouts	Hourly, Daily and Monthly
	Historical readouts available (historical traces of consumption is needed to calibrate/train models)	No Yes X; please, provide details: 1 year
	Price history available	No X Yes □; please, provide details:
Billing		
	Current tariff plan	Enercoop Tariff
	Current involvement in demand response programmes	No
Legal		
	Who owns the building?	Cooperativa Eléctrica San Francisco de Asís
	Is an agreement needed to access data for demo purposes?	No Yes, owner consent is required X Yes, consent from owner and building occupants is required
	Is an agreement needed to take actions over assets for demo purposes?	No Yes, owner consent is required X Yes, consent from owner and building occupants is required

3.4.2.3 Nursing House

3.4.2.3.1 Building Information

Information required	
Name of building	Nursing House "La purísima"
Location (coordinates)	<mark>69</mark> 23337.21 - 4235744.68
Structural information (e.g. surface, dimensions, floors, areas, etc.)	3 floors of 250 m ² each one
Usage (e.g. purpose, occupants, working times)	Nursing House - 50 occupants
Available equipment	
Sensors (please focus especially on occupancy and environmental sensors, e.g. temperature, humidity, luminance, IAQ, etc.)	No X Yes □; please, provide details:





	Controllable assets (please focus especially on energy hungry assets, e.g. HVAC, lighting, pool equipment, etc.)	No X Yes \Box ; please, provide details:
	Local electricity generation (emphasis on RES)	No 🗆 Yes X; PV plant of 18.45 kWp
	Storage (incl. Electric Vehicles)	No X Yes □; please, provide details:
	Smart meters/ Power analysers	No Ves X; please, provide details (with emphasis on frequency of metering and when the data can become accessible to you or a third party): Models: - ZIV 5CTD-EIC - ZIV 5CTME2C47536 AVF
	Building Management System	No X Yes : please, provide details (e.g. about make, capabilities and connected assets):
	Others	
Approx	. building annual electricity consumption	96,471 kWh
A <mark>p</mark> prox	annual electricity production (if RES)	26,213 kWh
Meteri	ng	
	Are you metering particular areas/assets demand independently? (sub-metering)	No X Yes ; please, provide details (e.g. how, which assets, their importance to building consumption, etc.):
	Frequency of readouts	Hourly, Daily and Monthly
	Historical readouts available (historical traces of consumption is needed to calibrate/train models)	No 🗌 Yes X ; please, provide details: 1 year
	Price history available	No X Yes \Box ; please, provide details:
Billing		
	Current tariff plan	Enercoop Tariff
	Current involvement in demand response programmes	Νο
Legal		
	Who owns the building?	Residencia La Purísima
	Is an agreement needed to access data for demo purposes?	No 🗆 Yes, owner consent is required X





	Yes, consent from owner and building occupants is required \Box
	No 🗆
Is an agreement needed to take actions over assets for demo purposes?	Yes, owner consent is required ${\sf X}$
	Yes, consent from owner and building occupants is
	required 🗆

3.4.2.4 Enercoop Headquarters

3.4.2.4.1 Building Information

Information required	
Name of building	Headquarters Electric Cooperative San Francisco de Asís
Location (coordinates)	<mark>69</mark> 1821.56 – 4233692.98
Structural information (e.g. surface, dimensions, floors, areas, etc.)	3 floors of 250 m ² each one
Usage (e.g. purpose, occupants, working times)	Offices
Available equipment	
Sensors (please focus especially on occupancy and environmental sensors, e.g. temperature, humidity, luminance, IAQ, etc.)	No Yes X; please, provide details:
Controllable assets (please focus especially on energy hungry assets, e.g. HVAC, lighting, pool equipment, etc.)	No X Yes \Box ; please, provide details:
Local electricity generation (emphasis on RES)	No 🗆 Yes X; PV plant of 12 kWp
Storage (incl. Electric Vehicles)	No 🗌 Yes X ; please, provide details: 1 EV
Smart meters/ Power analysers	No Yes X; please, provide details (with emphasis on frequency of metering and when the data can become accessible to you or a third party): Models: - ZIV 5CTD-EIC - ZIV 5CTME2C47536 AVF





	Building Management System	No X Yes □; please, provide details (e.g. about make, capabilities and connected assets):
	Others	
Approx	x. building annual electricity consumption	76,200 kWh
Approx	x. annual electricity production (if RES)	15,907 kWh
Meter	ing	
	Are you metering particular areas/assets demand independently? (sub-metering)	No X Yes \Box ; please, provide details (e.g. how, which assets, their importance to building consumption, etc.):
	Frequency of readouts	Hourly, Daily and Monthly
	Historical readouts available (historical traces of consumption is needed to calibrate/train models)	No 🗌 Yes X ; please, provide details: 1 year
	Price history available	No X Yes \Box ; please, provide details:
Billing		
	Current tariff plan	Enercoop Tariff
	Current involvement in demand response programmes	No
Legal		
	Who owns the building?	Cooperativa Eléctrica San Francisco de Asís
	Is an agreement needed to access data for demo purposes?	No Yes, owner consent is required X Yes, consent from owner and building occupants is required
	Is an agreement needed to take actions over assets for demo purposes?	No Yes, owner consent is required X Yes, consent from owner and building occupants is required

3.4.2.5 Enercoop Industrial plant

3.4.2.5.1 Building Information

Information required





Name of building	Industrial Plant Technical Department of the Cooperative
Location (coordinates)	692966.09 - 4234829.60
Structural information (e.g. surface, dimensions, floors, areas, etc.)	Industrial Building: 1,000 m ² Offices: 250 m ² Courtyard: 1,200 m ²
Usage (e.g. purpose, occupants, working times)	Warehouse, Technical Department, Control Centre
Available equipment	
Sensors (please focus especially on occupancy and environmental sensors, e.g. temperature, humidity, luminance, IAQ, etc.)	No Yes X; please, provide details:
Controllable assets (please focus especially on energy hungry assets, e.g. HVAC, lighting, pool equipment, etc.)	No X Yes □; please, provide details:
Local electricity generation (emphasis on RES)	No 🗌 Yes X; PV plant of 40 kWp
Storage (incl. Electric Vehicles)	No 🗌 Yes X; please, provide details: 1 EV
Smart meters/ Power analysers	No Yes X; please, provide details (with emphasis on frequency of metering and when the data can become ac- cessible to you or a third party): Models: - ZIV 5CTD-EIC
Building Management System	No X Yes \Box ; please, provide details (e.g. about make, capabilities and connected assets):
Others	
Approx. building annual electricity consumption	78,800 kWh
Approx. annual electricity production (if RES)	50,959 kWh
Metering	
Are you metering particular areas/assets demand independently? (sub-metering)	No X Yes ; please, provide details (e.g. how, which assets, their importance to building consumption, etc.):
Frequency of readouts	Hourly, Daily and Monthly
Historical readouts available (historical traces of consumption is needed to calibrate/train models)	No \Box Yes X ; please, provide details:




		1 year	
	Price history available	No X Yes : please, provide details:	
Billing			
	Current tariff plan	Enercoop Tariff	
Current involvement in demand response programmes		No	
Legal		·	
	Who owns the building?	Cooperativa Eléctrica San Francisco de Asís	
	Is an agreement needed to access data for demo purposes?	No Yes, owner consent is required X Yes, consent from owner and building occupants is required	
	Is an agreement needed to take actions over assets for demo purposes?	No Yes, owner consent is required X Yes, consent from owner and building occupants is required	

3.4.3 WiseEVP Pilot Site details checklist

3.4.3.1 Infrastructure

Charge points			
Manufacturer	INGETEAM, CIRCUTOR		
Model	INGEREV CI	ΤY	
Wodel	RVE-WB		
How many charge points will be available at demo site?	3 (one of th	em th	ne WG FastV2G)
Please provide database with charge points details, including GIS information (geojson, postgis)			
Are charge points remotely accessible to third parties?	Yes 🗆		No 🗆





If yes, please specify proto- col	TBC (OCPP)
Are charge points currently man- aged by any control system of your own?	Yes 🗆 No 🗙
If yes, please specify third party integration possibili- ties (API, protocol)	

Extra infrastructure			
Are the charge points part of a larger facility?	Yes X		
Are the charge points part of a larger facility!	No 🗆		
If yes, will the facility participate in WiseGRID demonstrators	Yes X		
(WiseCORP)?	No 🗆		
Are other elements (batteries, solar panels) installed or planned to be in-	Yes X		
stalled alongside the charge points?	No 🗆		
	Yes X		
If yes	No 🗆		
Could they be monitored as part of the demonstrator?			
Could they be controlled as part of the demonstrator?	Yes		
	No X		

3.4.3.2 Electric vehicles

Electric vehicles	
Manufacturer	Renault
Model	Renault ZE 40
in ouch	Renault Kangoo
How many vehicles will be available at demo site?	2
Database with electric vehicle de- tails	
Are vehicles currently monitored? If yes, please specify	Yes 🗆 No X
Details of hardware at vehi-	





cle	
Details of monitoring sys- tem	
Data retrieved from vehi- cles	
Frequency of data readout	

3.4.3.3 Scheduling systems

Scheduling systems		
Are you currently using any system for EV vehicle availability schedul- ing? (e.g. times when vehicle is re- quired by the organization, ex- pected distances to travel, vehicle booking)	Yes 🗆	No X
If yes, could you provide details on the information handled by this system (availability scheduling, min. charge constraints, etc.)		

3.5 KYTHNOS

The demonstration area of the current Pilot Site corresponds to the electrical system of Kythnos, a Greek island and municipality in the Western Cyclades with a population of 1,632 people. Kythnos is not interconnected either to the mainland grid or to any other neighbouring islands' electricity grids; hence Kythnos Island's electrical system constitutes a single-island insular system. The main coordinator of this Pilot Site is the Aegean Energy and Environment Agency (AEGEA). AEGEA's strategic objective is to increase the share of RES in islands' energy mix and promote technologies and practices that encourage the efficient and rational use of energy.

3.5.1 WG Cockpit Pilot Site details checklists

3.5.1.1 Set-up		
Information required		
Database of distribution grid assets, including GIS in	nformation (geojson, postgis,)	
Single-wire diagrams of distribution grid (including trotechnical assets,) – MV and LV (PSSE raw,)	g topology, line characterization, impedances, elec-	Х
3.5.1.2 Integration with DSOs syst	ems	

SCADA





Manufacturer	EFACEC (in progress, not yet implemented on Kythnos)			
Model	ScateX+ 15.7.5 (in progress, not yet implemented on Kythnos)			
Will it be available for monitoring?	Yes X		No 🗆	
Type of monitored signals (node volt- ages, line currents, switches and pro- tective device states,)	Feeder voltage, line current at feeder, feeder protective device state, feeder switches state, power factor values of lines at feeder point.			
Frequency of data acquisition	Measureme measured amount. States of sw every time interrogation their state had a chang	ents quar witch a ch on o in tl ge of	are acquired either every 1 min or every time a natity changes by a value greater that a specified ning elements or other equipment are transmitted nange in their state occurs. Once per day a general f all control signals is performed in order to update the central system, independently of whether they f state or not.	
Approx. amount of monitored signals in demo site				
Will it be available for controlling field assets (self-healing features)?	Yes 🗆		No 🗆	
Which protocol is available for inte- gration with third parties?	IEC 60870-5	5-10	1/104	

		-
AMI/AMR		
Manufacturer		
Model		
Approx. number of smart meters in demo site		
Communication with Smart Meters (GPRS, PLC, etc.)		
Frequency of readouts from smart meters	15 min	
Frequency of readouts from concen- trators		
Which protocol is available for inte- gration with third parties?		

3.5.1.3 Field devices





relays, transformers)?	
Which elements are you able to con- trol from your SCADA (switches)?	None yet

3.5.1.4 RES and Electric Vehicles

RES								
	1. Wind farm 165 kW of installed power (production has stopped).							
Which RES units are present in your	2. Wind farm 500 kW of installed power (production has stopped).							
distribution grid? Please provide de- tails (number of units, types, average peak power, ratio compared to over-	3. Three small PV stations of 238.25 kWp in total (a 98.25 kWp station and two 70kWp stations) installed and fully operating (low voltage distributed generation).							
all demand)	4. Repowering process for a 0.8 MW wind turbine has started and installation of the new unit is expected by end of 2018.							
Are you currently monitoring produc- tion of those units? How? (SCADA, AMI, Protocols)	Production of wind farms could be monitored in the Diesel Power Station through Diesel Power Station SCADA (MAS), with some ad- ditional implementation on the wind farm side. Production of Photovoltaic installations is not being monitored.							
Are you in position of controlling RES units? (production curtailment, power factor) How? (direct control, signal- ling to third party)	Wind farms could be submitted to production curtailments through Diesel Power Station SCADA (MAS), with some additional implementation on the wind farm side.							

Electric Vehicles				
Are there electric vehicle charging sta- tions deployed in your distribution grid? Please provide details (number of units, demand profile, ratio com- pared to overall demand)	None yet			
Are you currently monitoring demand of those units? How? (SCADA, AMI, Protocols)				
Are you in position of controlling the operation of the charging points? (start/stop operations, limit supply) How? (direct control, signalling to third party)				

5.5.1.5 POwer Station	
SCADA System	
Type of SCADA	
Type of Units	Seven diesel gen-sets are operating at the power station (2 x MITSUBISHI S16R-PTA with nominal power 1,275MW, 1 x





MITSUBISHI with nominal power 1,250MW a	nd 4 x MWM
TBD603V12 with nominal power 0.53 MW)	

3.5.2 WiseCORP and WG STaaS VPP Pilot Site details checklists

Information required Name of building **Desalination plant at Merichas** Location (coordinates) Structural information (e.g. surface, dimensions, floors, areas, etc.) Usage (e.g. purpose, occupants, working Two desalination units with maximum capacity of 300 m³/day times) each $- 600 \text{ m}^3/\text{day}$ in total. Available equipment Sensors (please focus especially on occupancy and environmental sensors, e.g. No X Yes ; please, provide details: temperature, humidity, luminance, IAQ, etc.) Controllable assets (please focus espe-Yes : PLC unit (ON/OFF), Pumps for sea water, desalinated cially on energy hungry assets, e.g. HVAC, water and saline residuals. lighting, pool equipment, etc.) Local electricity generation (emphasis on No RES) Storage (incl. Electric Vehicles) No Smart meters/ Power analysers No **Building Management System** No Other Approx. building annual electricity consumption Approx. annual electricity production (if RES) Metering Are you metering particular areas/assets No demand independently? (sub-metering) Frequency of readouts None Historical readouts available (historical traces of consumption are needed to cal-No \Box Yes \Box ; please, provide details: ibrate/train models) Price history available No \Box Yes \Box ; please, provide details:

3.5.2.1 Building information





Billing	
Current tariff plan	
Current involvement in demand response programmes	None
Legal	
Who owns the building?	Municipality of Kythnos
Is an agreement needed to access data for demo purposes?	Yes, owner consent is required
Is an agreement needed to take actions over assets for demo purposes?	Yes, owner consent is required

3.5.2.2 Available controllable assets

Information required	
Manufacturer/Model	Siemens/ PLC SIMATIC S7-300
Available protocol for monitoring/control (please elaborate on how the asset set- points or measurements can be ac- cessed)	Modbus
Is it possible to capture the setpoints that users apply (e.g. temperature on ther- mostats or dimming levels)?	No 🗆 Yes 🗆 I do not know X
Controllability restrictions (technical, le- gal, contractual, comfort)	
Energy demand of asset – frequency of readouts	
When are the readouts available to you or to third parties?	
Are these readings personal/sensitive da- ta according to European or national leg- islation?	l do not know
Energy demand of asset – historical readouts available	

3.5.2.3 Tariff information

Information required											
Provide a list the retailers that offer tar- iffs that can be applied to your buildings	One retailer supplies energy to the island (P.P.C. S.A.).										
What types of time-of-use tariffs are Only the residential customers have the option to be cha											





there (single period, 2 periods, 3 periods, etc.)	by a different tariff during 02:00-08:00 and 15:30-17:30 from the 1st of November until the 30th of April and during 23:00-07:00 from the 1st of May until the 31st of October.
For time-of-use tariffs, what is the mini- mum reading frequency for consumption (1 hour, 15 minutes, etc.)	
Is there a differentiation of tariffs based on active power? Please provide infor- mation.	
Is there a differentiation of tariffs based on voltage? Please provide information.	
Are there any other types of differentia- tion and/or restrictions that limit the se- lection of a tariff plan? Please provide in- formation.	
Are dynamic price tariffs available in your region or by your supplier? Is your build- ing eligible for them? Please provide in- formation.	
Any other comments/remarks regarding tariff ruling in your country?	

3.5.3 WiseEVP Pilot Site details checklist

3.5.3.1 Infrastructure

Charge points								
Manufacturer								
	Technical specs:							
	Mode 3 AC charging according to IEC 61851-1:2017							
	3phase, nominal voltage 230/400 V							
	OCPP 1.6 ready							
	Communication protocol IEC 61851							
Model	Protection IP 5 <mark>4 acco</mark> rding to EN/IEC 60529							
	Pollution level 3 according to IEC 61439-1							
	One or two sockets							
	Nominal power for each socket at 22 kVA/7 kVA for 3phase/1phase respectively.							
	Maximum current per phase for each socket: 32A.							
How many charging points will	10 (expected)							





be available at demo site?	
Database with charging points details, including GIS information (geojson, postgis)	During an interactive workshop with Kythnos locals at the end of April, the participants were asked to propose 10 locations for charging points on the map of Kythnos. Currently, these proposals are being discussed with the DSO during a spatial and EV planning analysis process.
Are charging points remotely accessible to third parties?	Yes
If yes, please specify pro- tocol	TCP/IP
Are charging points currently managed by any control system of your own?	Νο
If yes, please specify third party integration possibilities (API, proto- col)	

3.5.3.2 Electric vehicles

Electric vehicles	
Manufacturer	TBD from procurement process
Model	TBD from procurement process
How many vehicles will be available at demo site?	10
Database with electric vehicle details	
Are vehicles currently monitored? If yes, please specify	No
Details of hardware at vehicle	
Details of monitoring system	
Data retrieved from vehicles	
Frequency of data readout	

3.5.3.3 Scheduling systems

Scheduling systems

Are you currently using any system for EV vehicle availability scheduling? (e.g. times when vehicle is required by the organization, expected distances to travel, vehicle booking...)

If yes, could you provide details on the information handled by this system (availability scheduling, min. charge constraints, etc.)





4 UPCOMING SYSTEMS AND DATA

4.1 MESOGIA

Mesogia Pilot Site infrastructure is currently being upgraded in order to be able to fully host the WiseGRID tools that have been selected. The following list presents the planned hardware upgrade of the Pilot Site.

- 1 CHP (Combined Heat and Power) module EDA is at the final stage of purchasing the module which will be installed at its premises. It will be used for WiseCORP and is expected to be installed no sooner than December 2018.
- CHP infrastructure ICCS has purchased a CHP (Vitobloc 200 6/15) and has started installing it, so there is some pending infrastructure (e.g pipes). It will be used for WiseCORP. It is expected to be installed and ready for operation by December 2018.
- Server system It is the required hardware for the Big Data platform. It will be used for all tools and will be available on August 2018.

4.2 TERNI

ASM Terni infrastructure is currently being upgraded in order to be able to fully host the WiseGRID tools that have been selected. The following list presents the planned hardware upgrade of the Pilot Site.

- 1 Electric Vehicle Renault ZOE 22kWh. It will be used for WiseEVP and is expected to be available by June 2018.
- 1 Electric Vehicle Nissan Leaf 30kWh. It will be used for WiseEVP, but the day of availability is not known yet.
- 1 Fast Charger It will be used for WiseEVP, but the type and day of availability have not been defined yet.

4.3 FLANDERS

The Flanders Pilot Site infrastructure is currently being upgraded in order to be able to fully host the Wise-GRID tools that have been selected. The following list presents the planned hardware upgrade of the Pilot Site.

- 5 to 7 Battery systems Battery systems including batteries and single-phase battery inverter will be commissioned from Varta (5 household systems) and Ampère Energy (1 or 2 3-phase systems). They will be used for WG Staas/VPP. Varta is awaiting regulatory approval to install it in Belgium and Ampère is currently awaiting data of 2 test sites for further design.
- Ecopower is working on the installation of more H2020 Nobel Grid Smart Home controllers to be able to control up to 8 extra heat pumps in the Ghent area through the SMX. They are expected to be available July 2018.
- Together with the local co-operative Energent, Ecopower is working on the installation of up to 50 smart meters with SMX in the Ghent area. They are expected to be available December 2018.
- The local co-operative Energent is working on the installation of more individual and communityowned PV plants. They are expected to be installed throughout the project.

4.4 CREVILLENT

Crevillent Pilot Site infrastructure is currently being upgraded in order to be able to fully host the WiseGRID tools that have been selected. The following list presents the planned hardware upgrade of the Pilot Site.





- SCADA upgrade Current SCADA is being upgraded to a newer version. It will be used for WG Cockpit for real-time collection of measurements from substations and monitoring the status of fault passage detectors. It is expected to be available on July/August 2018.
- Integration of HVAC It will take place at the headquarters of Cooperative Crevillent and will be used for WiseCORP.
- OCPP protocol It needs to be confirmed that is available at Enercoop headquarters. It will be used for the integration with WiseEVP.
- PV and charging station submetering data from the Enercoop Industrial Plant.
- The WG FastV2G will be deployed in Crevillent but ITE needs to perform some tests in advance. Currently, the vehicles compatible with V2G technology are the Nissan Leaf and the Nissan E-NV200 van. So, these are the two types of vehicles that would enable us to demonstrate V2G technology. By the beginning of June, ITE will have a Nissan Leaf in renting mode during the same month to conduct the tests in ITE premises.
- To demonstrate the fast charge of the WG FastV2G, any vehicle compatible with CHAdeMO will serve. Possible list of cars to be used in Crevillent: Nissan Leaf (V2G) · Nissan E-NV200 (V2G) · Mitsubishi Fuso Ecanter · Mitsubishi Outlander · Toyota Prius · Kia Soul · Tesla Model S (with CHAdeMO adapter) · Mitsubishi I-MIEV · Mahindra E20 · Peugeot Partner · Peugeot Partner Tepee Electric · Citroen C-Zero · Peugeot Ion · Citroen Berlingo · Mitsubishi Minicab-MiEV Truck · Mitsubishi Minicab-MiEV · Mazda Demio · Bollinger B1 · Honda Fit · Subaru Stella · BD Otomotiv eKangoo · BD Otomotiv eDucato · BD Otomotiv eFiorino · BD Otomotiv eTrafic.

4.5 KYTHNOS

Kythnos Pilot Site infrastructure is currently being upgraded in order to be able to fully host the WiseGRID tools that have been selected. The following list presents the planned hardware upgrade of the Pilot Site.

- 5 to 10 Battery systems Battery systems including batteries and single-phase battery inverter will be commissioned from Varta. They will be used for WG Staas/VPP. The first two units are expected by August 2018 and the rest by December 2018.
- 5 to 10 Charging stations They will be used for WiseEVP. The first two units are expected by November 2018 and the rest by February 2019.
- 5 to 10 Electric Vehicles They will be used for WiseEVP. The first two units are expected by November 2018 and the rest by February 2019.

5 PLANNING AND TIMELINE OF THE INTEGRATION AND DEPLOYMENT ACTIVITIES

At this chapter the timeline and planning of the integration and deployment activities is presented and explained. The timeline follows the basic milestones of the WiseGRID project. Tool developers and Pilot Site leaders, with the support of ICCS and ETRA, are the main responsible partners of these two activities. Integrated lab-testing and deployment activities will prepare the ground for the demonstration activities, the final stage of the WiseGRID project.

5.1 INTEGRATED LAB-TESTING ACTIVITIES

It is a task that mainly refers to the tool developers of the consortium, supported by ICCS and ETRA, and its main scope is to test and evaluate the performance and interoperability of the WiseGRID tools in an integrated laboratory environment and refine them, so as to be ready for the final deployment period. For that purpose, a set of integration steps will be identified and realized for each tool. Each integration step should





produce a product that implements a related functionality of the tool. The sequence of the integration steps and the complete schedule will be also described. Additionally, part of this task is also the resolution and documentation (if necessary) of possible integration problems that might occur during this activity. At Figure 8, the timeline of the Integrated Lab-testing activities is presented.

As it can be seen from the timeline, this activity starts at month M19, which corresponds to May 2018, and ends at month M24 which is October 2018. At M19 and M24 the deliverables D14.1 and 14.2 need to be submitted accordingly. From the end of M19 up to M21 (July 2018), the tool developers need to identify and describe the required integration steps and their sequence. Also, during the same period the final refinement of the WG tools will take place and the tool developers will close all the pending issues regarding the functionalities of developed tools. The end of this period, July 2018, coincides with the deadline of the deliverables D5.2, D7.2, D9.2, D11.2 and D13.2 which correspond to the refinement and lab-testing for each of the developed tools. At the same month (M21), the main part of the activity starts, which is the integrated lab-testing, based on the steps and following the sequence, as defined at the previous period. This period ends at the end of M24 (October 2018) and the outcomes will be presented in the deliverable D14.2. During the integrated lab-testing period, the resolution and, in cases, documentation of the occurring problems will take place. At the end of the Integrated lab-testing period, all developed tools are expected to be ready for the final deployment.

5.2 PRELIMINARY DEPLOYMENT

The main responsible partner for this activity, the Pilot Site leaders, will collaborate with the tool developers and will be supported by ICCS and ETRA in order to deploy one or two, at most, of the WiseGRID tools at their premises and evaluate their performance. The scope of this activity is, on the one hand, to give a feedback to the tool developers for the performance of the deployed tools at real world conditions and on the other hand to activate the Pilot Sites so as to prepare their infrastructure before the final deployment. At the end of this activity, it is expected that each of the developed tools will be operating and will be fully functional at one Pilot Site, and at each Pilot Site at least one WG tool will be fully deployed. At Figure 9, the timeline of the preliminary deployment activities is presented.

According to the timeline this activity starts at M22, which is August 2018, and ends at M26, December 2018. As it can be observed, this activity overlaps with the integrated lab-testing activity, described at the previous paragraph. This allows the tool developers to get a feedback from the real-world testing and refine even more, if required, the developed tools. This activity starts with the preparation of the Pilot Sites in order to be able to host the defined tool. Three months have been allocated for this preparation, from August (M22) to October (M24). Big data infrastructure preparation, although a part of the general preparation of the Pilot Site, is defined as a different activity since it requires the active involvement of more partners (not only the Pilot Site leader). On M23, September 2018, the tool developers will start preparing the tool for its deployment at the specific Pilot Site. This means that all the required interfaces, parameters, submodules need to be calibrated accordingly and tested separately, if necessary. The actual preliminary deployment will start on October 2018 (M24) and will last until November 2018 (M25). The last month, December 2018 (M26) will be used for the evaluation and assessment of the results coming from the operation of the tools at the specific Pilot Site. In parallel with the deployment phase, the documentation of the occurring issues will take place along with the way to resolve them. Finally, it needs to be mentioned that DPIA establishment, which is part of the preliminary deployment activity, has been decided to take place during June 2018 (M20). This month precedes the officially specified period of preliminary deployment, but since it is an independent but necessary activity, it was considered best to happen in this month.

5.3 FINAL DEPLOYMENT

Similar to the preliminary deployment activity, the responsible partners for this activity are the Pilot Site leaders who will collaborate with the tool developers and will be supported by ICCS and ETRA in order to





achieve the final deployment of the selected WiseGRID tools at the respective demo sites. Both the Pilot Site leaders and the tool developers with the experience gained from the preliminary deployment will deploy and evaluate the operation of all the WG tools with the final goal being the preparation for the demonstration activities that follow. At Figure 10, the timeline of the preliminary deployment activities is presented.

As it is expected, the main activities required for the final deployment are more or less the same as for the preliminary deployment. The main difference is that in this case all the specified tools will be deployed at the corresponding Pilot Sites. Although this seems to be a heavy burden for only four months, it is expected that the experience gained during the preliminary deployment will help significantly and in various ways. The tool developers will have debugged the tools and will have already prepared them for deployment. Many issues related to real environments will have been already dealt with. As a result, only the Pilot Site specific requirements will need to be met. The same is expected for the Pilot Site leaders, as well. According to the timeline this activity starts at M27, which is January 2019, and ends at M30, April 2019. The final deployment starts with the preparation of the Pilot Sites in order to be able to host the defined tools. Slightly more than two months have been allocated for this preparation, from January (M27) to beginning of March (M29). Big data infrastructure preparation, although a part of the general preparation of the Pilot Site, is defined as a different activity for the same reason as before. This activity runs in parallel with the preparation of the Pilot Site but is not expected to be time consuming since most of the issues concerning the required hardware and software are expected to have already been solved during preliminary deployment. The tool developers will start preparing the tools for the deployment at the various Pilot Sites also at the same period. The actual final deployment will start at the end of M28 (February 2019) and will last until the beginning of M30 (April 2019). At the end of M29 (March 2019) and during the whole M30 the evaluation and assessment of the results coming from the operation of the tools at the Pilot Sites will take place. Note that this month is also the deadline for the deliverable D15.1 "WiseGRID integrated ecosystem preliminary deployment and demonstration". At the end of the final deployment all tools should be able to operate at the specific Pilot Sites, so that the demonstration period could start.





	M19					1		M20			P.		MZ1			1		MZZ					M23			1		M24		
	2	25	May '18	1.	82	1		Jun '18	78	35	4		Jul '18	10	25	ų.	X3	Aug'18				1	Sep '18		25	12	78	Okt '18		23
	Week 1	Week	Z Week 3	Week 4	Week 5	Week1	Week Z	Week3	Week4	Week 5	Week 1	Week Z	Week 3	Week 4	Week 5	Week	1 Week2	Week3	Week	4 Week5	Week1	Week 2	Week3	Week4	Week 5	Week 1	Week 2	Week 3	Week 4	Week 5
					u coamer																									
	-		- 10	10	4		12	12	4			12	10	h.1		12	- 10				12				12	12				10
	-													1	ntegrated	Lab Tes	ting													
			1	1)	1 Contraction		10	6			12		0	1		1	19	8		1	1				1	19				1
Deliverables			D14.1	6														D14.2												
Integrated Lab-Testing Timeline and Planning						-																								
Identification & Description of Integration Steps by Tool																6														
Finish with the pending issues of the WG Tool development						45		n.	D5.2, D7.	.2, D9.2, D	11.2, D13.	2	17																	
Integrated Lab Testing based on the defined steps													h		1					10	h.				he second	k. N				
Integration Problems Documentation		-										8	10	(7). 	ND	10	112	100	55		lu.				lu.	la.	<i>17.</i> 8			-

Figure 8 – Timeline for integrated lab-testing activities.

D14.1 Analysis of the Demo sites technical data integration and demonstration planning





	M20 Jun 18			2	M21					M22 Aug '18				M23 Sep '18				100	M24					M25					M26							
				6	Jul 18				60									Okt '18				-	Nov'18				98	Dec '18								
	Week1	Week Z	Week 3	Week4	Week 5	Week1	Week Z	Week3	Week 4	Week 5	Week I	Week Z	Week 3	Week 4	Week 5	Week1	Week Z	Week 3	Wee	ek4 Week	5 Week	1 Wee	kZ Wee	k3 1	Neek4 1	Veek 5	Week I	Week	Z Week 3	Week 4	Week5	Week 1	Week Z	Week 3	Week 4	Week5
															-			-	-		-	_	_	-					-							
															Preliminary Deployment																					
Big Data infrastructure Prel iminary Deployment																																				
Pliot Site Preparation for Preliminary Deployment of Specific WS Tool		DP	A Dep loyn	nent																																
WG Tool Preparation for Preliminary Deployment @ Specific Pilot Site																																				
Preliminary Deployment of WG Tools at Pilot Sites																																				
A sesament & Evaluation of Proliminary Deployment Results																																				
Preliminary Deployment Problems																																				

Figure 9 – Timeline for preliminary deployment activities.





	M27					M28 Feb '19						8 - S	M29			M30						
	Jan '19				s						3	Mar '19	2	<u> </u>	Apr '19							
	Week 1	Week 2	Week 3	Week 4	Week 5	Week1	Week 2	Week 3	Week 4	Week 5	Week 1	Week 2	Week 3	Week 4	Week 5	Week 1	Week 2	Week 3	Week 4	Week 5		
Big Data Infrastructure Final																						
Deployment																						
Pilot Site Preparation for Deployment of All Supported WG Tool																						
WG Tools Preparation for Deployment at All Defined Pilot Sites																						
Final Deployment of WG Tools at All Pilot Sites																						
Assessment & Evaluation of Final									-													

Figure 10 – Timeline for final deployment activities.





6 CONCLUSIONS

The integration and demonstration of 9 different products into a single framework will not be an easy task and the tool developers and Pilot Sites have to be properly prepared. That requires a good overview of the systems already in place and the necessary extra requirements such as storage, big data specifications...

The data collected from the Pilot Sites indicates that they are correctly prepared to test and evaluate all the WG tools and Use Cases that they indicated. In addition, it can be highlighted that the deployment and utilization of the respective WiseGRID products will be useful for improving their respective businesses, as they will facilitate faster dispatching of their everyday tasks.

In order to better prepare this demonstration phase, a planning and a timeline have been created according to the WiseGRID milestones. The goal of this process is to deploy the tools in an organized way in order to receive reliable and exploitable feedback, learn from the first deployments and avoid future problems in the definitive deployment.

In the future deliverables of WPs 14 and 15, all the tasks that are needed to be carried out for the proper demonstration of the WiseGRID framework will be further explained and additionally, specific information (divided per Pilot Site) will be shown in order to correctly test and assess its performance.

7 REFERENCES AND ACRONYMS

7.1 REFERENCES

[1] NOBEL GRID Project, [Online]. Available: http://nobelgrid.eu/.

7.2 ACRONYMS

	Table 5	Actorityms list	
Acronyms List			
AMI	Advanced Metering Infrastr	ructure	
AMR	Automatic Meter Reading		
API	Application Programming Ir	nterface	
DC	Direct Current		
DMS	Distribution Management S	System	
DPIA	Data Protection Impact Asso	sessment	
DSO	Distribution System Operate	tor	
ESCO	Energy Service COmpany		
EV	Electric Vehicle		
EVSE	Electric Vehicle Supply Equi	ipment	

Table 3 – Acronyms list





G2V	Grid To Vehicle
GIS	Geographical Information System
HV	High Voltage
ICT	Information and Communication Technology
LV	Low Voltage
MV	Medium Voltage
OCCP	Open Charge Point Protocol
PLC	Programmable Logic Controller
PV	Photovoltaic
RES	Renewable Energy Source
RESCO	Renewable Energy Service COmpany
RTU	Remote Terminal Unit
SCADA	Supervisory Control And Data Acquisition
STaaS	Storage as a Service
TSO	Transmission System Operator
V2B	Vehicle To Building
V2 <mark>G</mark>	Vehicle To Grid
VPP	Virtual Power Plant
WG	WiseGRID